




FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL PBG - Portland Use of Building Commercial Date 11/17/05
 Name and address of owner of appliance Pepsi Bottling Group
250 Canal Rd. Portland, ME
 Installer's name and address Nelson Mechanical Systems Mark J. Smith
194 Mead Rd Auburn, ME 04210 Telephone 207-782-0727

Location of appliance:
 Basement Floor
 Attic Roof

Type of Fuel:
 Gas Oil Solid
ELECTRIC HEAT

Appliance Name: RTU-1 RTU-2

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:
 Master Plumber # _____
 Solid Fuel # _____
 Oil # _____
 Gas # _____
 other HVAC TECH

Type of Chimney: N/A
 Masonry Lined
 Factory built _____

Metal
 Factory Built U.L. Listing # _____

Direct Vent
 Type _____ uL# _____

Type of Fuel Tank
 Oil N/A
 Gas

Size of Tank _____

Number of Tanks _____

Distance from Tank to Center of Flame _____ feet.

Cost of Work: \$ 11,000 -
Permit Fee: \$ 120 -

Approved

Approved with Conditions

Fire: _____
 Ele.: _____
 Bldg.: _____

See attached letter or requirement

Inspector's Signature

Date Approved

Signature of Installer _____

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-1695	Date Applied For: 11/18/2005	CBL: 148 A008001
------------------------------	--	----------------------------

Location of Construction: 250 CANCO RD	Owner Name: BOTTLING GROUP LLC	Owner Address: 1 PEPSI WAY	Phone:
Business Name:	Contractor Name: Nason Mechanical Systems	Contractor Address: 194 Merrow Road Auburn	Phone (207) 782-0707
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	
Proposed Use: Commercial/ install electric rooftop unit		Proposed Project Description: install electric rooftop unit	

Dept: Zoning **Status:** Approved **Reviewer:** Jeanine Bourke **Approval Date:** 12/08/2005
Note: **Ok to Issue:**

Dept: Building **Status:** Approved **Reviewer:** Jeanine Bourke **Approval Date:** 12/08/2005
Note: **Ok to Issue:**

1) Installation shall comply with 2003 International Mechanical Code.

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Cptn Greg Cass **Approval Date:** 12/06/2005
Note: **Ok to Issue:**

1) Install to comply with NFPA 70

November 8, 2005

05322

David Bisson
Acadia Development, Inc.
PO Box 8135
Portland, ME 04104-6792

RE: HVAC Support, Pepsi Canco Road


Dear David,

Associated Design Partners, Inc. has visited the above referenced building in order to review and document the existing roof framing conditions of the 1967 building addition. This was done in order *to* determine if the existing roof framing is acceptable for carrying the additional load of a proposed rooftop cooling unit.


Based upon the original design drawing of the building addition dated February 8, 1967 by Alonzo J. Harriman Associates, Inc. the existing 10B4 steel purlins spaced at 48" on-center are acceptable to support the proposed load of single rooftop cooling unit Trane model TCC018, at **any** location along its length. See attached support frame plan and detail for additional information.



Please call should you have any additional questions.

Sincerely,



Aaron S. Wilson, P.E.
Structural Engineer





- USE EPOXY EMBEDMENT FOR ALL WELDS
- DESIGN & DETAIL BASE UPON TRANS ROOFTOP UNIT MODEL TCC018 @ 281# TOTAL WEIGHT

ASSOCIATED DESIGN PARTNERS INC.

80 Leighton Road
Falmouth, Maine 04105

Office: (207) 878-1751
Fax: (207) 878-1788
E-Mail: adp@adpengineering.com

PROJECT NUMBER
05322

PROJECT TITLE
PEPSI HVAC SUPPORT

DATE
11/8/05

SHEET 1 OF 1