

Fire Suppression System Design Specifications

Notes

System Materials

| Item Number | Description | Quantity |
|---------------|--|----------|
| 87-120016-001 | ADP Nozzle | 4 |
| 87-120017-001 | F Nozzle | 2 |
| 60-120005-001 | WHDR-600 Cylinder/Valve, 6 Gallon | 1 |
| 60-120073-001 | 1 1/4" NPT Mechanical Gas Valve | 1 |
| 60-120099-001 | Universal Control Head Assembly | 1 |
| 60-120110-001 | Remote Manual Release, Combination | 1 |
| WK-282666-000 | ML-500 Link 500 F (260 C), ML, Orange | 1 |
| WK-282664-000 | ML-360 Link 360 F (182 C), ML, Unpaint | 1 |
| 60-120064-001 | Universal Link Detector Housing Kit (A+) | 2 |



Designed & Installed by:
Firesafe Equipment
PO Box 1355
Auburn, ME 04211
207-784-7525

For:
HARMON'S CLAMS