Location of Construction:	Owner:		Phone:		Permit No: 9 8 1 0 6 9
257 Canco &d	Portland Retir	ement besidence	(503)	370-7070	
Owner Address:	Lessee/Buyer's Name:	Phone:	Business	Name:	T PERMIT ISSUED
2250 McGilchrist St SE \$200 Sa	lem, 08 97302				
Contractor Name:	Address:	Phon			Permit Issued:
Jet Beating, Inc.	1935 Silverton Rd H		97303		SEP 2 2 1998
Past Use:	Proposed Use:	COST OF WOR		PERMIT FEE:	
		\$ 142,060.		\$ 730.00	CITY OF PORTLAND
		FIRE DEPT.	Approved	INSPECTION:	CITT OF FUNILARD
Retirement Housing			Denied	Use Group: Type:	7 1001
					Zone: CBL:
December 1		Signature.	Par at	Signature:	Zoning Approval:
Proposed Project Description:		PEDESTRIAN A		S DISTRICT (P.A.D.)	Zoring Approva.
		Action:	Approved	/	Special Zone or Reviews:
Install RVAC Sys				/	□ □ Shoreland
1			Denied		□ □ Wetland
			/	TD	☐ Flood Zone
		Signature:		Date:	□ Subdivision □ Site Plan maj □minor □mm □
Permit Taken By:	Date Applied For:	15 September 199			a one i ian maj alimioi alimi a
83%			~/		Zoning Appeal
1. This permit application does not preclude the A	Applicant(s) from meeting applica	ble State and Federal rules.			□ Variance
2. Building permits do not include plumbing, se	ntic or electrical work				☐ Miscellaneous
					☐ Conditional Use☐ Interpretation
- L	, ,	of issuance. False informa-	-		☐ Interpretation ☐ Approved
tion may invalidate a building permit and stop	o all work				□ Denied
					Historic Preservation
			IN PERM	150	☐ Not in District or Landmark
			WITH RES	IT ISSUED UIREMENTS	☐ Does Not Require Review
			. UEQ	UIREALED	☐ Requires Review
				LIMENTS	Action:
				. 0	Action.
	CERTIFICATION				□Appoved
I hereby certify that I am the owner of record of the	named property, or that the propos	sed work is authorized by the	he owner of 1	ecord and that I have be	
authorized by the owner to make this application a	s his authorized agent and I agree	to conform to all applicab	le laws of thi	is jurisdiction. In additio	on, Denied
if a permit for work described in the application is	issued, I certify that the code offic	ial's authorized representa	tive shall hav	ve the authority to enter	all Date:
areas covered by such permit at any reasonable ho	ur to enforce the provisions of the	code(s) applicable to such	n permit		Date:
		16 September	1996		
SIGNATURE OF APPLICANT	ADDRESS:	DATE:	THE P. LEWIS CO.	PHONE:	
		211111			Wa (-20
					K('/7K
RESPONSIBLE PERSON IN CHARGE OF WORK	K, TITLE			PHONE:	CEO DISTRICT 🔏
380 tr	well Beels Ones Access	O B BIM BUT B	alatia Piri		
white-Per	rmit Desk Green-Assessor's	Canary-D.P.W. Pink-Pi	ublic rile l'	vory Card-Inspector	

BUILDING PERMIT REPORT ADDRESS: 257 CarcoRd DATE: 21 SepT. REASON FOR PERMIT: eTirement PERMIT APPLICANT USE GROUP BOCA 1996 CONSTRUCTION TYPE CONDITION(S) OF APPROVAL This Permit is being issued with the understanding that the following conditions are met: Approved with the following conditions: 4/429 This permit does not excuse the applicant from meeting applicable State and Federal rules and laws. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection) Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing 2.5 not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used. the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2 Foundations anchors shall be a minimum of 1 1/2" in diameter, 7" into the foundation wall, minimum of 12" form corners of 2.6 From corners of foundation and a maximum 6'o.c. between bolts. (Section 2305.17) Precaution must be taken to protect concrete from freezing. Section 1908.0 3. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than I-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996) All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211 Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-I, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 34" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0) Headroom in habitable space is a minimum of 7'6". (Section 1204.0) Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise.(Section 1014.0) The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4 Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or

exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height

ĩ.

).

Ι.

not more than 44 inches (11,18mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1018.6)

- 13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. Section 1010.1
- All vertical openings shall be enclosed with construction having a fire rating of at lest one (1)hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) Section 710.0
- 15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment. Table 302.1.1
- All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2

- 17. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. Section 921.0
- 18. The Fire Alarm System shall be maintained to NFPA #72 Standard.
- 19. The Sprinkler System shall maintained to NFPA #13 Standard.
- 20. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
- 21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
- 23. Ventilation shall meet the requirements of Chapter 12 Sections 1210. Of the City's Building Code. (crawl spaces & attics)
- 24. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade.
- 25. All requirements must be met before a final Certificate of Occupancy is issued.
 - All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code. (The BOCA National Building Code/1996).
- Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)

Hease read and implement HeacTunes	System	Shall b	equirements. E 1957ai	Hed as	per	The M	20
4-actures	reguirent	21/5			/		

	*	······································					

Satural Hollses Building Inspector

o: Lt McDougall, PFD

Marge Schmuckal, Zoning Administrator

26.

28. 29.

30.

31.

32.



CITY OF PORTLAND, MAINE

Department of Building Inspection

15 Sept 19 98
Received from It Weating a fee
of Seven hundred Hurty Toollars \$ 730 -
for permit to install alter for permit to alter for permit to for permit
at 257 Carres Rd Est. Cost \$ 142,600
Ch \$715
Inspector of buildings

THIS IS NOT A PERMIT

No work is to be started until PERMIT CARD is actually posted upon the premises. Acceptance of fee is no guarantee that permit will be granted. PRESERVE THIS RECEIPT. In case permit cannot be granted the amount of the fee will be refunded upon return of the receipt less \$5.00 or 10% whichever is greater.

WHITE - Applicant's Copy YELLOW - Office Copy PINK - Auditors Copy

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

Building or Use Permit Pre-Application

Attached Single Family Dwellings/Two-Family Dwelling

Multi-Family or Commercial Structures and Additions Thereto

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTE**If you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Addressof Construction (include Portion of Building): 257 Canco Rd.						
Total Square Footage of Proposed Structure	Square Footage of Lot	·				
Tax Assessor's Chart, Block & Lot Number Chart# 149 Block# B Lot# 001	owner: Portland Retirement Residen	Telephone#: (503) 370 - 7070				
Owner's Address: 2250 McGilchrist StSE, 200 Salem OR 97302	Lessee/Buyer's Name (If Applicable)	Cost Of Work: Fee \$\\42,060\\\\2,060\\\\\\\\\\\\\\\\\\\\\\\\\\				
Proposed Project Description: (Please be as specific as possible) Retinement Center - Install HVAC work.						
Contractor's Name, Address & Telephone Jet Heating, Inc. (503) 363-2334 1935 Silver ton Rd. NE, Salem, OR 97303 Rec'd By J.						
Current Use:	Proposed Use:					

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

•All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.
•All plumbing must be conducted in compliance with the State of Maine Plumbing Code.

•All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.

•HVAC(Heating, Ventililation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code

You must Include the following with you application:

1) ACopy of Your Deed or Purchase and Sale Agreement 2) A Copy of your Construction Contract, if available

3) A Plot Plan/Site Plan

Minor or Major site plan review will be required for the above proposed projects. The attached checklist outlines the minimum standards for a site plan.

4) Building Plans

Unless exempted by State Law, construction documents must be designed by a registered design professional.

A complete set of construction drawings showing all of the following elements of construction:

- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: Date: 0//0/44	cinorec inc provisions of the c		
		MM	

Building Permit Fee: \$25.00 for the 1st \$1000.cost plus \$5.00 per \$1,000.00 construction cost thereafter.

Additional Site review and related fees are attached on a separate addendum

OF PORTLAND, ME

5 1998



Jet Heating, Inc.

1935 Silverton Rd N.E. P.O. Box 7362 Salem, OR 97303

Telephone (503) 363-2334 Fax (503) 363-2622

July 10, 1998

Colson & Colson

ATTN: TERRY JOHNSON

Re: Portland, ME

Dear Terry:

The following is a breakdown of the items needed for the HVAC system.

Please let me know if you need any additional information.

•	Base bid\$1	15 000 00
•	Attic ventilators	1 680 00
	HP3 (split system heat pumps located in suites where roof lines will not	111,000,00
	receive through-the-wall pump) 2 shown on plans at \$2,700.00 each	.5.400.00
•	3 fire-rated access doors	300 00
•	10-ton revision kitchen	7 950 00
0	Cottages (13 units x \$450.00 each)	5 850 00
•	Fire/smoke dampers	.5.880.00
	TOTAL\$ 1	42.060.00

Items not included:

- Through-the-wall heat pumps by other. (Installation by Jet.)
- Condensate lines by plumber.
- Trenching, back fill, concrete, and backhoe operation for underground ducting provided by owner and layout and supervision by Jet.
- No propane piping or gas piping.
- No sales tax included.
- No high voltage wiring included.
- Concrete slab for AC3 (kitchen) by others.
- General framing for heat pumps supply, return ducting and chases by framing contractor.

Thanks for working with us!

Sincerely,

Jeff Zeeb

Vice President

tl

cc: file, Paul Glaunert