## Permit No: **Date Applied For:** CBL: City of Portland, Maine - Building or Use Permit 2013-00884 05/02/2013 149 G006001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Location of Construction: Owner Name: Owner Address: Phone: 159 CANCO RD CITY OF PORTLAND 389 CONGRESS ST **Business Name:** Contractor Name: Contractor Address: Phone 53 Industrial Way Portland Trust for Public Land Maine Bay Canvas (207) 878-8888 Lessee/Buyer's Name Permit Type: Phone: Lisa Preble 2077727424 Tents Proposed Project Description: Proposed Use: Park Erect 20' x 30' tent on Friday, May 3, 2013 and breakdown on Monday, May 6, 2013. Dept: Zoning **Approval Date:** 05/02/2013 Status: Approved Reviewer: Ann Machado Ok to Issue: Note: 05/03/2013 Dept: Building **Status:** Approved w/Conditions **Reviewer:** Jon Rioux **Approval Date:** Note: Ok to Issue: 1) Note: Applicant st. that the tent is open (no tent walls), or construction: stages/platforms, open flames, or electrical connections. 2) 108.2 Conformance. Temporary structures and uses shall conform to the structural strength, fire safety, means of egress, accessibility, light, ventilation and sanitary requirements of this code as necessary to ensure public health, safety and general 3) This permit DOES NOT authorize any construction activities. The tent/stage must be removed at the end of the event. 4) Approval is subject to compliance with City and State Food Codes per the Portland Public Health Dept. **Dept:** Fire **Status:** Approved w/Conditions Reviewer: Chris Pirone **Approval Date:** 05/03/2013

1) If the sides of the tents are to be enclosed at least two remotely located and marked exits shall be provided.

3) If the sides of the tents are to be enclosed at least two remotely located and marked exits shall be provided.

4) Tents shall have an approved fire resistant rating and maintain 10' between stake lines. No smoking or open flame allowed within

Ok to Issue:

Note: Approved per Capt. Pirone, JGR.

2) Cooking within the tents has not been reviewed and approved.

10'. Provide at least one 2A:10 BC fire extinguisher.