

**City of Portland, Maine - Building or Use Permit Application**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 09-0968	Issue Date:	CBL: 150 A003001
-----------------------	-------------	---------------------


Location of Construction: 40 QUARRY RD	Owner Name: BROWN J B & SONS	Owner Address: PO BOX 207	Phone:
Business Name:	Contractor Name: Fielding's Oil & Propane	Contractor Address: P.O. Box 364 Scarborough	Phone 2078833194
Lessee/Buyer's Name	Phone:	Permit Type: Tanks - Commercial	Zone: C-50

Past Use: Commercial	Proposed Use: Commercial - install a 1000 gallon tank Double wall in concrete container	Permit Fee: \$35.00	Cost of Work: \$35.00	CEO District: 4
		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied <i>* See Conditions</i>	INSPECTION: Use Group: <i>U</i> Type:	

Proposed Project Description: install a 1000 gallon Double wall in concrete container	Signature: <i>(KB)</i>	Signature: <i>(Handwritten)</i>
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input checked="" type="checkbox"/> Denied		
Signature:	Date:	

Permit Taken By: Ldobson	Date Applied For: 09/03/2009	<b>Zoning Approval</b>
-----------------------------	---------------------------------	------------------------

- This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..



<b>Special Zone or Reviews</b> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date:	<b>Zoning Appeal</b> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	<b>Historic Preservation</b> <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date:
---	---	--

SCANNED

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

11-03-09

DISCUSSED w/ Capt Gattusa -

OK to close

SIGNATURE FILED - Done per request

G.M.A.

**City of Portland, Maine - Building or Use Permit**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 09-0968	Date Applied For: 09/03/2009	CBL: 150 A003001
-----------------------	---------------------------------	---------------------

Location of Construction: 40 QUARRY RD	Owner Name: BROWN J B & SONS	Owner Address: PO BOX 207	Phone:
Business Name:	Contractor Name: Fielding's Oil & Propane	Contractor Address: P.O. Box 364 Scarborough	Phone: (207) 883-3194
Lessee/Buyer's Name	Phone:	Permit Type: Tanks - Commercial	

Proposed Use: Commercial - install a 1000 gallon Double wall in concrete container	Proposed Project Description: install a 1000 gallon Double wall in concrete container
---	--

Dept: Zoning	Status: Approved	Reviewer: Marge Schmuckal	Approval Date: 09/08/2009	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Dept: Building	Status: Approved with Conditions	Reviewer: Tammy Munson	Approval Date: 09/16/2009	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
1) Installation shall comply with 2003 International Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules				
Dept: Fire	Status: Approved with Conditions	Reviewer: Capt Keith Gautreau	Approval Date: 09/10/2009	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
1) The Fire Department will require the appropriate signage for the tank or area.				
2) Install shall comply with NFPA 30.				
3) Install shall comply with all manufacture's specifications.				

**Comments:**  
9/8/2009-mes: I gave back to Lannie to correct spelling on the permit on 9/4/09 - I received it back on 9/8/08





FILL IN AND SIGN WITH INK

# APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 40 (Suite #3) QUARRY RD. 150 A3 Use of Building Commercial Date 8-31-09  
Name and address of owner of appliance Radford Transportation

Installer's name and address Fielding's oil co. Scarborough Me. 04070-0364 Telephone P.O. Box 364

**Location of appliance:**

Basement       Floor outside  
 Attic             Roof

**Type of Fuel:**

Gas       Oil       Solid

**Appliance Name:** 1000 gal Tank

U.L. Approved  Yes  No

Will appliance be installed in accordance with the manufacture's installation instructions?  Yes       No

IF NO Explain: N/A

**The Type of License of Installer:**

Master Plumber # \_\_\_\_\_  
 Solid Fuel # \_\_\_\_\_  
 Oil # MS10008276  
 Gas # \_\_\_\_\_  
 Other \_\_\_\_\_

**Type of Chimney:**

Masonry Lined  
Factory built N/A

Metal  
Factory Built U.L. Listing # N/A

Direct Vent  
Type N/A UL# N/A

**Type of Fuel Tank**

Oil  
 Gas

Size of Tank 1000 gal Double wall in cement container

Number of Tanks 1

Distance from Tank to Center of Flame N/A feet.

**Approved**

Fire: \_\_\_\_\_  
Ele.: \_\_\_\_\_  
Bldg.: \_\_\_\_\_

**Signature of Installer** Dan Fielding

**Approved with Conditions**

See attached letter or requirement

## BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

to schedule your inspections as agreed upon

Permits expire in 6 months, if the project is not started or ceases for 6 months.

The Owner or their designee is required to notify the inspections office for the following inspections and provide adequate notice. Notice must be called in 48-72 hours in advance in order to schedule an inspection:

By initializing at each inspection time, you are agreeing that you understand the inspection procedure and additional fees from a "Stop Work Order" and "Stop Work Order Release" will be incurred if the procedure is not followed as stated below.

A Pre-construction Meeting will take place upon receipt of your building permit.

  X   Final inspection conducted by the Fire Department is required at completion of work.

Certificate of Occupancy is not required for certain projects. Your inspector can advise you if your project requires a Certificate of Occupancy. All projects DO require a final inspection.

If any of the inspections do not occur, the project cannot go on to the next phase, REGARDLESS OF THE NOTICE OR CIRCUMSTANCES.

**CERIFICATE OF OCCUPANICES MUST BE ISSUED AND PAID FOR, BEFORE THE SPACE MAY BE OCCUPIED.**

\_\_\_\_\_  
Signature of Applicant/Designee

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature of Inspections Official

\_\_\_\_\_  
Date

*Mail*



Read ST


40

Quarry Rd  
Buildings

11 1/2 Feet  
From Building



13'



25'

Cement  
Cont.

Tank is

1000 gal Double wall

Parking Lot



Drive way

Quarry Rd.



# CITY OF PORTLAND, MAINE

Department of Building Inspections

## Original Receipt

\_\_\_\_\_ 9.3 20 09 \_\_\_\_\_

Received from Filling Oil

Location of Work 40 Quarry Rd

Cost of Construction \$ \_\_\_\_\_ Building Fee: \_\_\_\_\_

Permit Fee \$ 35 Site Fee: \_\_\_\_\_

Certificate of Occupancy Fee: \_\_\_\_\_

**Total:** 35

Building (IL) \_\_\_\_\_ Plumbing (I5) \_\_\_\_\_ Electrical (I2) \_\_\_\_\_ Site Plan (U2) \_\_\_\_\_

Other tank

CBL: 150 A3

Check #: 5631 - **Total Collected \$** 35

**No work is to be started until permit issued.  
Please keep original receipt for your records.**

Taken by: \_\_\_\_\_

WHITE - Applicant's Copy  
YELLOW - Office Copy  
PINK - Permit Copy