## CITY OF PORTLAND FIRE PREVENTION BUREAU

380 Congress Street, Portland, Maine 04101 fireprevention@portlandmaine.gov (207) 874-8400

## NOTICE OF VIOLATION AND ORDER TO CORRECT

October 26, 2017

| Responsible Party 1:                  |     |                              |  |  |
|---------------------------------------|-----|------------------------------|--|--|
| BROWN J B & SONS                      |     |                              |  |  |
| PO BOX 207                            |     |                              |  |  |
| PORTLAND, ME 04112                    |     |                              |  |  |
|                                       |     |                              |  |  |
| Location                              | CBL | Inspection Date              |  |  |
| Location<br>40 QUARRY RD- RTS Packagi |     | Inspection Date<br>8/31/2017 |  |  |
|                                       |     | •                            |  |  |

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

## You must send this form to the Fire Prevention Bureau no later than 11/15/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

| Violation  | Proposed Date of Completion |
|--|-----------------------------|
| PORTLAND FIRE DEPARTMENT CHAPTER 10 SECTION 12 KNOX BOX REQUIRED;<br>Knox Boxes are required for all buildings with fire alarm or suppression systems.<br>Need keys made for Knox Box  | //                          |
| PORTLAND FIRE DEPARTMENT CHAPTER 10 4.6.1, 4.6.2 UNIT/SUITE NUMBERS NOT MARKED; 4.6.1 Residential units shall be designated using numerals. 4.6.2 The first numeral of each residential unit shall be the floor designation. Identify Business Name or Suite # | //                          |
| NFPA 13- 8.1.2 SPRINKLER SYSTEM REQUIRES SERVICE; System valves and gauges shall be accessible for operation, inspection, tests, and maintenance.  Identify Riser Locations  | //                          |
| FINAL DATE OF COMPLETED VIOLATION(S)   | //                          |
| FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)   | //                          |

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

## VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau <u>prior to the deadline</u> to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

| Date            | Responsible Party      |  |
|-----------------|------------------------|--|
| Date            | Responsible Party      |  |
| SEEN AND AGREED |                        |  |
| Date            | Fire Prevention Bureau |  |