Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 01/31/14



1 inch = 100 feet

Pressure Zone: 267

PORTLAND WATER DISTRICT
225 Douglass Street
Portland, ME 04104
Asset Management and Planning Dept.

Legend

- Air Valve
- Blow Off
- By Pass
- Distribution
- Transmission
- Connection
- Attribute Change
- Reducer
- Hydrant
- Hydrant Control
- Combined Service
- Domestic Service
- Fire Service
- Private Hydrants
- Meter Pits
- Manhole
- CSO
- Gravity
- Force
- Contours

Hydrant Flow Testing Data

217 Read Street
Portland

N

This map depicts flow testing data for the selected hydrants from PWD's asset management system. Note: a static pressure with a zero residual pressureand a flow hydrant that is the same as the test hydrant depicts a single-hydrant static pressure-only test.

Drawn By: BSJ	Prepared For: Scott Garland Sprinkler Systems Inc.
Scale: As Noted	Date: January 7, 2014