READ STREET SELF-STORAGE

217 READ STREET
PORTLAND, ME 04103



BASEMENT LEVEL - 4,846 S.F.
1/8" = 1'-0"

- NFPA "13 WET ORDI
  EXISTING PIPE SC
- 18" MINIMUM CLEAR
  OF ANY STORAGE
  DEFLECTOR
- INSTALL BRANCH LINES AT 0-4½ TO
  0-5½ FROM DECK TO ℄ OF PIPING

48 / 155° ½"x½" OR BRASS UPRIGHTS
RELIABLE FIFRSL K=5.6 RA1425

CITY OF PORTLAND, MAINE — RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/31/14