CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/16/15

NEW DECK ELEVATION
PRESSURE TREATED WOOD - FRAMING, DECKING, BALLISTERS

NEW DOOR - EXTERIOR
FIBERGLASS
INSULATED TEMPERED GLASS

Specs: DECK

1) circular handrail to be wall mounted on house.
2.) Ledger (2"x10") attached to building by screws.
3.) 16" on center Joists
4.) 1½" joists hangers
5.) 36" handrail / Ballister Hgtd.
6.) Stairs 4' wide