



CITY OF PORTLAND  
FIRE PREVENTION BUREAU  
380 Congress Street, Portland, Maine 04101  
fireprevention@portlandmaine.gov  
(207) 874-8400

**NOTICE OF VIOLATION AND ORDER TO CORRECT**

October 5, 2016

<b>Responsible Party 1:</b> BRIDGHAM KEVIN S 67 UNIVERSITY ST PORTLAND, ME 04103		<b>Responsible Party 2:</b> Bridgham Kimberly 204 Spurwink Rd Scarborough, ME 04074
<b>Location</b> 67 UNIVERSITY ST	<b>CBL</b> 151 D011001	<b>Inspection Date</b> 9/27/2016
<b>Inspector</b> Brendan Joyce	<b>Inspection Type</b> FP Routine Inspection	<b>Status</b> Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must complete the proposed date of completion column by proposing a reasonable timeframe to remedy each violation. This form must be received by the Fire Prevention Bureau no later than 10/30/2016. The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

**YOUR FAILURE TO SUBMIT A PLAN OF ACTION BY THE DATE PROVIDED, OR TO CORRECT ANY VIOLATION WITHIN THE APPLICABLE TIME FRAME, MAY RESULT IN LEGAL ACTION AGAINST YOU, THE IMPOSITION OF CIVIL PENALTIES, AND THE PURSUIT OF OTHER LEGAL REMEDIES.**

<b>Violation</b>	<b>Proposed Date of Completion</b>
<b>NFPA 54 UNPROTECTED OUTSIDE GAS LINE;</b> See NFPA 54 regarding requirements for outdoor unprotected gas lines. The LPG gas regulator on the side of the driveway needs protection.	11/6/16

**ATOR CERTIFICATION**

to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

10/31/16  
Date

*[Signature]*  
Responsible Party

\_\_\_\_\_  
Date

\_\_\_\_\_  
Responsible Party

**SEEN AND AGREED**

10/31/2016  
Date

Capt. Petrucci  
Fire Prevention Bureau