
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager STOKES DAVID &		Inspector Jon Rioux	Inspection Date 7/31/2007
Location 81 UNIVERSITY ST	CBL 151 D014001	Status Re-Inspect 30 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.2	Interior			Basement	
Violation:	Interior floors, walls, ceilings and doors				
Notes:	(b) Interior floors, walls, ceilings and doors. Every floor, wall, ceiling, and door shall be in a structurally sound condition and in good repair and shall be substantially vermin proof. Repair the basement wall damaged by "mold".				

Comments: