

FC901 Battery Calculations Worksheet

ver. 1.3
7-Feb-2012

Fixed Field	Enter Numbers Here
Calculated Field	Choose a value

Ref. No Maine DEA
Submitted By Eastern Fire Services

FC901 Panel		Standby (A)	Alarm (A)
Main Board		0.178	0.203
Device Current Draw		0.02868	0.02868
NAC 1		0	1.352
NAC 2		0	0
Aux power (external)			
FCACity Tie	No		
FSD901 Remote Annun.	2	0.0012	0.0014

Devices	Qty			
HFP-11 / 8713				
HFPO-11 / 8710				
HFPT-11 / 8712				
OOHC941				
OOH941	1	0.00068	0.00068	
OH921				
OP921				
HI921				
FDCIO422				
HMS / 8700-S/D/M				
HTRI-S / 8702	10	0.014	0.014	
HTRI-D / 8703	1	0.0014	0.0014	
HTRI-R / 8704	1	0.0014	0.0014	
HZM / 8705				
HCP / 8706	8	0.0112	0.0112	
ILED / 8726				
Total	21	0.02868	0.02868	System OK

Total Current	0.20668	1.58368
----------------------	---------	---------

Standby Time	24	4.960
---------------------	----	-------

Alarm Time	5	0.132
AH required (no reserve)		5.092
Battery Reserve	125%	

AH Required (with reserve)	6.365366667	System OK
-----------------------------------	-------------	------------------