

•  
•  
•  
•  
•  
•  
•  
•

389 Congress St.Rm 315  
Portland, ME 04101  
Phone: (207)874-8700  
Fax: (207)874-8716

facsimile transmittal

**To:** Michael Charek **From:** Mike Nugent  
**Fax:** 761-7260 **Date:** September 24, 2002  
**Phone:** **Pages:** 1  
**Re:** Radcliffe Glenn (153 A025)

☐ Urgent ☐ For Review ☐ Please Comment ☒ Please Reply ☐ Please Recycle

Preliminary review has been done and I need the following information :

Fire wall & Fire partition details demonstrating compliance with section 707.6.2 and 711.0 and Sound transmission ratings for these assemblies, any penetrations and the protection of these penetrations.

Draft stopping in compliance with 721.0

Stairway details including treads, risers, nosing, headroom and width

Foundation anchor detail and spacing

Garage Fire separation detail, including door schedule (current submission does not meet code)

What type of chimneys/heating systems?

Headers? Egress Windows?? Fasteners??

Let's discuss the type of lally column and spacing on page S2, it appears that the spacing is excessive based on girder span tables in the IRC.

• • • • •