CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/20/15

2009 IECC Energy Efficiency Certificate

Insulation Rating	R-Value
Ceiling / Roof	39.00
Wall	21.00
Floor / Foundation	30.00
Ductwork (unconditioned spaces):	____

Glass & Door Rating	U-Factor	SHGC
Window	0.34	0.70
Door	0.26	0.70

Heating & Cooling Equipment	Efficiency
Heating System: _____	_____
Cooling System: _____	_____
Water Heater: _____	_____

Name: _____ Date: _____

Comments: