



**FIRST FLOOR FIRE ALARM PLAN**  
SCALE: 1/8"=1'-0"

RESERVED FOR CITY STAMP

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	4/29/2015

**CUNNINGHAM**  
**Security Systems**

10 Princes Point Road, Yarmouth, Maine 04096  
Office: 207.846.3350 • Fax: 207.846.6080

**FCP Battery Calculation** 4/28/2015

PROJECT NAME: 276 CANCO ROAD  
Required Standby Time: 24 Hours  
Required Alarm Time: 5 Minutes

Regulated Load in Standby			
Device Type	Number of Devices	Current (Amps)	Total Current (Amps)
MS-10UD Main Circuit Board	1	0.13300	0.13300
Smoke Detectors	18	0.00005	0.00090
Heat Detectors	4	0.00000	0.00000
Pull Stations	10	0.00000	0.00000
TOTAL STANDBY LOAD 0.13390			
Regulated Load in ALARM			
Device Type	Number of Devices	Current (Amps)	Total Current (Amps)
MS-10UD Main Circuit Board	1	0.28200	0.28200
Smoke Detectors	18	0.13000	2.34000
Heat Detectors	4	0.00000	0.00000
Pull Stations	10	0.00000	0.00000
NAC-1 (See voltage drop calcs for device quantity)	1	1.02000	1.02000
NAC-2	X	0.25500	0.25500
NAC-3	X	0.00000	0.00000
NAC-4	X	0.00000	0.00000
TOTAL ALARM LOAD 3.89700			

**Battery Requirements**

Standby Load	Current (Amps)	Required Standby Time in Hours
Standby Load	0.13390	X 24.00000 = 3.21360
Alarm Load	3.89700	X 0.08333 = 0.32475
Total Ampere Hours (before derating factor) 3.53835		
Derating Factor	X	= 1.2
TOTAL AMPERE HOURS REQUIRED 4.24602		

**BATTERIES TO BE PROVIDED (2 - 12V) 7 AH**

**NAC Circuit Voltage Drop Calculation** 4/28/2015

Project Name: 276 CANCO ROAD  
Circuit Number: NAC-1

Nominal System Voltage: 20.4 volts  
Minimum Device Voltage: 16 volts  
Distance from source to 1st device: 25  
Wire Gauge for balance of circuit: 14

Max Output Current: 1.33 amps  
Total Circuit Current: 1.020 amps

**Circuit is within limits**

Device	Device Current	Distance previous device	Voltage at Device	Drop from source	Percent Drop
Device 1	0.079	22	20.24	0.16	1%
Device 2	0.176	55	19.86	0.54	3%
Device 3	0.212	29	19.76	0.64	3%
Device 4	0.079	12	19.72	0.68	3%
Device 5	0.079	23	19.67	0.73	4%
Device 6	0.079	26	19.62	0.78	4%
Device 7	0.079	42	19.56	0.84	4%
Device 8	0.079	22	19.54	0.86	4%
Device 9	0.079	30	19.52	0.88	4%
Device 10	0.079	286			
Totals					

**NAC Circuit Voltage Drop Calculation** 4/28/2015

Project Name: 276 CANCO ROAD  
Circuit Number: NAC-2

Nominal System Voltage: 20.4 volts  
Minimum Device Voltage: 16 volts  
Distance from source to 1st device: 30  
Wire Gauge for balance of circuit: 14

Max Output Current: 0.255 amps  
Total Circuit Current: 0.255 amps

**Circuit is within limits**

Device	Device Current	Distance previous device	Voltage at Device	Drop from source	Percent Drop
Device 1	0.079	60	20.35	0.05	0%
Device 2	0.176	30	20.32	0.08	0%
Totals					

276 CANCO ROAD

PORTLAND, MAINE 04103

CALCS & FIRST FLOOR FIRE ALARM PLAN

DRAWN: JPB UNICAD JOB #15144

CHECKED: WAYNE B. HAWES NCEIT IV 90486

DATE: 4/29/2015

SCALE: 1/8" = 1'-0"

**UNICAD**  
INC.

5754 W. 40TH ST.  
SUITE 200  
DENVER, CO 80231-1010  
WWW.UNICAD.NET

**FA-2**