

3/5/03 Inspected Paint Booth w/ Mike Collins
OK to proceed. JB An ammendment is submitted
for repair after fire for other damaged areas JB

3/13/03 Inspected paint Booth for controls and
ventilation activation w/ Mike Collins. Need to
check w/ Lt. Mac for fire suppression & Fan time
for de-activation. JB

3/19/03 LT Mac inspected - all ok JB
Close out