

#354958

Portland, Maine



Yes. Life's good here.

September 10, 2015

DEVLIN JEROME E & ERIN M DEVLIN

71 READ ST # 3

PORTLAND, ME 04103

CBL: 155 E015001

Located at 71 READ ST

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

A handwritten signature in cursive script that reads "A/C Keith Santora".

Portland Fire Department

Fire Prevention Bureau

**CITY OF PORTLAND
PORTLAND FIRE DEPARTMENT**

380 Congress Street
Portland, Maine 04101

Inspection Violations

| | | | |
|---|---------------------------|--------------------------------|--|
| Owner/Manager DEVLIN JEROME E & | | Inspector Todd Zsiga | Inspection Date 9/9/2015 |
| Location 71 READ ST | CBL 155 E015001 | Status Failed | Inspection Type Fire Company-FP Routine Inspec |

| Code | Int/Ext | Floor | Unit No. | Area | Compliance Date |
|-------------|----------------|--------------|-----------------|-------------|------------------------|
|-------------|----------------|--------------|-----------------|-------------|------------------------|

1) 73.05

Violation: NFPA 101- 7.2.1.15.8 FIRE DOOR ASSEMBLY REQ REPAIR; DOOR OPENINGS NOT IN PROPER OPERATING CONDITION SHALL BE REPAIRED OR REPLACED WITHOUT DELAY.

Notes: FIRE DOORS REQUIRED THROUGHOUT

2) 73.15

Violation: NFPA 101- 31.3.1.1.1 VERTICAL OPENINGS NOT FIRE RATED; VERTICAL OPENINGS SHALL BE ENCLOSED OR PROTECTED IN ACCORDANCE WITH SECTION 8.6.

Notes: HOLE IN WALL AT BASE OF STAIRS B SIDE ENTRANCE STAIRWAY

3) 89.05

Violation: NFPA 1 EXCESSIVE/DISORDERLY STORAGE; REFERENCE NFPA 1 FOR EXCESSIVE FUEL-LOAD.

Notes: 2ND FLOOR REAR LANDING

4) 91.20

Violation: NFPA 70- 590.6 EXTENSION CORDS; Ground-fault protection for personnel for all temporary wiring installations shall be provided to comply with 590.6(A) and (B). This section shall apply only to temporary wiring installations used to supply temporary power to equipment used by personnel during construction, remodeling, maintenance, repair, or demolition of buildings, structures, equipment, or similar activities.

Notes: REAR STAIRWAY LIGHT FIXTURE

Comments:

STATE OF MAINE

DISTRICT COURT
Location: Portland
Docket No.

CITY OF PORTLAND and body politic and
Corporate, located in the County of
Cumberland and State of Maine,

Plaintiff,

v.

Jerome & Erin Devlin
Defendant

**FIRE PREVENTION AND PROTECTION
CODE VIOLATION**


(M.R. CIV. P. 80H AND 80k)

SUMMONS NUMBER: 354958

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 11/09/2015. I strongly urge you to contact Victoria Meserve at Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an in-person meeting to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 11/09/2015.

Dated:

9/17/15



Adam R. Lee, Esq. Bar No. 4143
Associate Corporation Council
City of Portland
389 Congress St
Portland, ME 04101
207-874-8480