



. . . Fire Protection by Computer Design

Sprinkler Systems, Inc.
2-4 Avon Street
P.O. Box 1285
Lewiston, Maine 04240
207-782-0104

Job Name : KING RESIDENCE
Building :
Location : 23 BAY STREET, PORTLAND, MAINE 04103
System : 1 OF 1
Contract : 11083
Data File : KINGRES211083.wxf

HYDRAULIC DESIGN INFORMATION SHEET

Name - KING RESIDENCE Date - 12-9-2011
Location - 23 BAY STREET, PORTLAND, MAINE 04103
Building - System No. - 1 OF 1
Contractor - REDFERN PROPERTIES Contract No. - 11083
Calculated By - SCOTT E. GARLAND Drawing No. - 1 OF 1
Construction: (X) Combustible () Non-Combustible Ceiling Height 7-6
OCCUPANCY - RESIDENTIAL - SINGLE FAMILY DWELLING

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 20.0 Gpm System Type
Listed Pres. at Start Point - 16.7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 20 x 20 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make RELIABLE Model RFC49
I Elevation at Highest Outlet - 68.167Feet Size 1/2 X 1/2 K-Factor 4.9
G Note: Temperature Rating 165 DEG
N DESIGN AREA #2 - 2ND FLOOR STORAGE AREA

Calculation Gpm Required 40.514 Psi Required 47.230 AT BASE OF RISER
Summary C-Factor Used: Overhead 150 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 7-28-2004 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 92 Elev.
R Residual (Psi) - 89 Other Well
Flow (Gpm) - 1433 Proof Flow Gpm
S Elevation - 50.0

P Location: ON OCEAN AVENUE AT READ STREET, 390-0 FROM BAY STREET

P Source of Information: PORTLAND WATER DISTRICT

Y

Pressure / Flow Summary - STANDARD

Sprinkler Systems, Inc.
KING RESIDENCE

Page 10
Date 12-9-2011

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
TYP	0.0	4.9	16.7	na	20.02	0.05	400	16.7
3	68.167	K = K @ DROP	17.39	na	20.02			
4	68.167	K = K @ DROP	18.2	na	20.49			
F	68.167		19.71	na				
E	59.5		35.78	na				
RT	59.5		37.1	na				
RB	51.0		47.23	na				
X	51.0		56.44	na				
X1	51.0		56.46	na				
X2	51.0		56.46	na				
TEST	50.0		56.9	na				

The maximum velocity is 13.65 and it occurs in the pipe between nodes 4 and F

Final Calculations - Hazen-Williams

Sprinkler Systems, Inc.
KING RESIDENCE

Page 11
Date 12-9-2011

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TYP to DROP	20.02	1.101 150	1T	9.563 0.0	0.500 9.562	16.700 0.0			K Factor = 4.90	
	20.02	0.0682		0.0	10.062	0.686			Vel = 6.75	
	0.0 20.02					17.386			K Factor = 4.80	
3 to 4	20.02	1.101 150		0.0 0.0	12.000 0.0	17.386 0.0			K Factor @ node DROP	
	20.02	0.0682		0.0	12.000	0.818			Vel = 6.75	
4 to F	20.49	1.101 150		0.0 0.0	6.000 0.0	18.204 0.0			K Factor @ node DROP	
	40.51	0.2512		0.0	6.000	1.507			Vel = 13.65	
F to E	0.0	1.101 150	4E 1T	15.3 9.563	24.167 24.863	19.711 3.754				
	40.51	0.2512		0.0	49.030	12.314			Vel = 13.65	
E to RT	0.0	1.101 150	1E	3.825 0.0	1.417 3.825	35.779 0.0				
	40.51	0.2512		0.0	5.242	1.317			Vel = 13.65	
RT to RB	0.0	1.38 120	1Z	3.0 0.0	8.500 3.000	37.096 8.681			* Fixed loss = 5	
	40.51	0.1263		0.0	11.500	1.453			Vel = 8.69	
RB to X	0.0	1.314 150	1E 1T	2.247 4.495	80.000 6.742	47.230 0.0				
	40.51	0.1061		0.0	86.742	9.207			Vel = 9.58	
X to X1	0.0	6.16 140	1T	43.037 0.0	360.000 43.037	56.437 0.0				
	40.51	0.0001		0.0	403.037	0.026			Vel = 0.44	
X1 to X2	0.0	12.34 140	1T	93.767 0.0	390.000 93.767	56.463 0.0				
	40.51	0.0		0.0	483.767	0.001			Vel = 0.11	
X2 to TEST	0.0	6.16 140		0.0 0.0	30.000 0.0	56.464 0.433				
	40.51	0.0001		0.0	30.000	0.002			Vel = 0.44	
	0.0 40.51					56.899			K Factor = 5.37	

Water Supply Curve (C)

Sprinkler Systems, Inc.
KING RESIDENCE

Page 12
Date 12-9-2011

City Water Supply:
C1 - Static Pressure : 92
C2 - Residual Pressure: 89
C2 - Residual Flow : 1433

Demand:
D1 - Elevation : 7.868
D2 - System Flow : 40.5141
D2 - System Pressure : 56.899
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 40.5141
Safety Margin : 35.097

