

Marge Schmuckal - shed permit application

From: Marge Schmuckal
To: cbreeze409@hotmail.com
Date: 9/10/2013 4:45 PM
Subject: shed permit application

409 Ocean Ave

159-E-006 #2013-02003

Hi Ken,

I have been reviewing your shed permit for compliance. Please note that your shed is required to be 5' from the rear and side property lines. You are only showing 3' to the rear property line. I can not issue this permit based on that shed placement. If you can revise your plot plan to show that you will have the minimum 5' to both property lines, I will be able to issue the permit.

If you have any questions, please do not hesitate to contact me either by e-mail or by phone: (207) 874-8695.

Marge Schmuckal
Zoning Administrator