

Grease Gutters provided? Grease cup At Fan base

Hood Clearance reduction to Combustibles design /specs:

18" plus Above Hood

Duct Clearance reduction to Combustibles design /specs:

3m grease duct wrap

Vibration Isolation System:

Air Velocity within the duct system .75 sp

Grease accumulation prevention system:

Cleanouts To be install in y joint up to main stack

Grease Duct enclosure 3m grease duct wrap

Exhaust Termination Roof X Wall _____

Fire Suppression System Done by other (Fire safe)

Exhaust fan mounting and clearance from the roof / wall or Combustibles:

18" off roof 40" above roof at top of fan

Exhaust fan distance from property lines 10'

Exhaust fan distance from other vents or openings 10'

Exhaust fan distance from adjacent buildings 10'

Exhaust fan height above adjoining grade 20'

Hood Specs

Style of Hood Canopy

Type of Filter Grease baffles

Height of filter above nearest cooking surface 36"

Capacity of hood CFM 3250 CFM

Make up Air system description and capacity

Make up air fan to sit on roof and return 2275 CFM into a plenum box to be install on front on hood