
12 Loraine st. Garage project

Christina Stacey <cstacey@portlandmaine.gov>
To: mattkeller13@gmail.com

Thu, Jan 12, 2017 at 2:55 PM

Hi Matt,

I was able to talk this over with my supervisor today. She said she would be OK with the creation of the peaked roof under the following conditions:

- 1) That the garage is proven to be at least 5 feet from the side property line (this may require that you enlist the services of a surveyor, as we discussed on the phone).
- 2) That the pitch of the roof does not exceed 3:12 (the plan you submitted is a little fuzzy so I can't tell exactly what the pitch says).

Let me know if you have questions about this information.

[Quoted text hidden]

[Quoted text hidden]

Sent from my iPhone

—
Chris Stacey - Zoning Specialist
Permitting & Inspections Department
City of Portland
389 Congress St.
Portland, ME 04101
(207) 874-8695
cstacey@portlandmaine.gov