TYPICAL - NOT TO SCALE

HAMMOND LUMBER COMPANY HAS SUPPLIED THIS DRAWING FOR ILLUSTRATIVE AND INFORMATIONAL PURPOSES ONLY. THE HOMEOWNER/CONTRACTOR IS RESPONSIBLE FOR ENSURING THAT THE MATERIALS CHOSEN WILL COMPLY WITH LOCAL BUILDING CODES AND/OR STANDARD BUILDING PRACTICES. HAMMOND LUMBER COMPANY SUGGESTS THAT ISn'T CUSTOMERS SEEK THE ASSISTANCE OF A REGISTERED ENGINEER OR ARCHITECT IF FURTHER INFORMATION IS NEEDED. THIS DRAWING IS NOT INTENDED TO BE USED AS A BASIS FOR CONSTRUCTION AND HAMMOND LUMBER COMPANY DISCLAIMS ANY RESPONSIBILITY IF THEY ARE SO USED.

A/113 CROSS SECTION

ROOF VENTILATION EAVE DETAIL TRUSS

Footing 8"x16"
Wall 8"x 3'10"
2 rows of ½ rebar in walls and footing
4" slab with wire Mesh
½" ancor bolts every 6'

Hammond Lumber Company
Toll free 1-866-HAMMOND
www.hammondlumber.com
Auburn · Bangor · Belgrade · Brunswick · Boston
Bucksport · Calais · Camden · Farmington · Fairfield · Farmington
Greenville · Lewiston · Lincoln · Millinocket · Oakland · Pittsfield · Portland · Skowhegan · Waterville · Wilton

DRAWINGS ARE PROVIDED BY HAMMOND LUMBER COMPANY AS A GUIDE TO CUSTOMERS AND ARE INTENDED FOR INFORMATIONAL AND ILLUSTRATIVE PURPOSES ONLY. THE INFORMATION PRESENTED IN THESE DRAWINGS MAY NOT REPRESENT THE BEST PRACTICE FOR CONSTRUCTION. THESE DRAWINGS SHOULD NOT BE USED AS A BASIS FOR CONSTRUCTION. HAMMOND LUMBER COMPANY SUGGESTS THAT ITS CUSTOMERS SEEK THE ASSISTANCE OF A REGISTERED ENGINEER OR ARCHITECT TO REVIEW BLUEPRINTS IF THE CUSTOMER DESIRES TO PROCEED FURTHER. HAMMOND LUMBER COMPANY DISCLAIMS ANY RESPONSIBILITY FOR CONSTRUCTION AND DRAWINGS UNDERSTOOD TO BE USED AS A BASIS FOR CONSTRUCTION AND HAMMOND LUMBER COMPANY DISCLAIMS ANY RESPONSIBILITY IF THEY ARE SO USED.

ABB	Thursday, February 9, 2017	REV.	
		11/29/16	2/9/2017
SSM	SCALE : AS NOTED	12/06/16	
		12/15/16	
FOR	3 OF 3	12/22/2016	1/29/2017

DRAWING # AD16255

MATT KELLER

21X23 GARAGE ADDITION

12 LORAINE ST PORTLAND

Approved
Approved as Noted
Revise and Resubmit
Date: 06/07/17