


CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

October 5, 2016

Responsible Party 1: PORTLAND ASSISTED LIVING LLC PO BOX 847 CARLSBAD, CA 92018		
Location 217 CANCO RD	CBL 160 E001001	Inspection Date 10/3/2016
Inspector Todd Zsiga	Inspection Type FP Routine Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must complete the proposed date of completion column by proposing a reasonable timeframe to remedy each violation. This form must be received by the Fire Prevention Bureau no later than 10/30/2016. The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

YOUR FAILURE TO SUBMIT A PLAN OF ACTION BY THE DATE PROVIDED, OR TO CORRECT ANY VIOLATION WITHIN THE APPLICABLE TIME FRAME, MAY RESULT IN LEGAL ACTION AGAINST YOU, THE IMPOSITION OF CIVIL PENALTIES, AND THE PURSUIT OF OTHER LEGAL REMEDIES.

Violation	Proposed Date of Completion
PORTLAND FIRE DEPARTMENT CHAPTER 10 SECTION 12 KNOX BOX REQUIRED; Knox Boxes are required for all buildings with fire alarm or suppression systems.	10/28/2016
NFPA 720- 5.5.6.1 CO ALARMS REQUIRED; The performance, location, and mounting of notification appliances used to initiate or direct action, evacuation or relocation of the occupants, or for providing information to occupants or staff, shall comply with the requirements of Chapter 6.	IMMEDIATELY install temporary alarms where required. Your signature below indicates that temporary alarms have already been installed.

ordered 10/20, conformation attached.
 Co's installed 10/21/2016. *J. White*



Thank you for your order with Knox Company. Please refer to this e-mail for information related to your order. If you have questions regarding your order, please call 866-625-4563 or reply to this e-mail.

Subject: ~~Knox Company Shipment Confirmation~~
Sales Order: **SO0001646009**

Billing Information

Billing Contact: Hawthorn Retirement
Address: 86 HOLIDAY DR PORTLAND, ME 04103-4368
Email: 214maint@HawthornRet.com
Phone: 207-772-1080

Shipping & Tracking Information

Ship To Name: Hawthorn Retirement
Address: 86 HOLIDAY DR PORTLAND, ME 04103-4368

Tracking Number(s): 092869924133642

All shipments are bound by: Terms & Conditions

Item(s) Shipped and Install Addresses

Shipped 10/20
Eta 10/26

ITEM	INSTALL ADDRESS
(1) 3261 - 3200 SURFACE, BLACK, HINGED, NO TS PS-48-0011-11-87	86 Holiday PORTLAND ME 04103

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

10/21/2016
Date

Joe Melito
Responsible Party

Date

Responsible Party

SEEN AND AGREED

10/25/2016
Date

Capt Petrucci
Fire Prevention Bureau