



CITY OF PORTLAND, MAINE  
Department of Building Inspection

# Certificate of Occupancy

LOCATION 1003 Washington Ave.

Date of Issue 7/31/91

Issued to Port Resources, Inc.

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 91/2348 has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire

APPROVED OCCUPANCY

Adult foster home

- Limiting Conditions:
1. Third floor to be used as office space only.
  2. Sprinkler head to be installed over boiler supplied by 3/4" copper or 1-inch steel pipe.
  3. Exterior railings to be made graspable as required by B.C.A. 325.2.4
  4. Second floor kitchen to be removed.

This certificate supersedes certificate issued

Approved:

7/31/91

(Date)

*Mark [Signature]*  
Inspector

*[Signature]*  
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises and ought to be maintained from order to ensure when property changes hands. Copy will be furnished to owner or lease for use only.