

Permit # **924203** City of Portland

BUILDING PERMIT APPLICATION Fee \$600.00 Zone            Map #           

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Part Congreg of Jehovah's Witnesses Phone # 773-6171

Address: 355 Canco Rd. 04105

LOCATION OF CONSTRUCTION 355 Canco Rd. Sub:           

Contractor:            Phone #           

Est. Construction Cost: \$8,000.00 Proposed Use: storage facility

Building Dimensions L            W            Total Sq. Ft.           

# Stories:            # Bedrooms            Lot Size:           

Is Proposed Use: Seasonal Condominium            Conversion           

Explain Conversion to construct storage facility as per plans

\$60.00

For Official Use Only

Date: September 28, 1992

Inside Fire Limit           

Blade Code           

Time Limit           

Estimated Cost: \$8,000.00

City of Portland

PERMIT ISSUED

OCT - 7 1992

Street Frontage Provided:            Back            Side            Side           

Review Required:            Provided Setbacks:           

Zoning Board Approval: Yes            No            Date:           

Planning Board Approval: Yes            No            Date:           

Conditional Use:            Variance            Floodplain Yes            No           

Special Exception            Other:           

Other:           

CEILING:           

1. Ceiling Joists Size:            Spacing           

2. Ceiling Strapping Size:            Size           

3. Type Ceiling:            Size           

4. Insulation Type:            Size           

5. Ceiling Height:            Span            Action           

Roof:            Span            Action           

1. Truss or Rafter Size:            Span            Action           

2. Sheathing Type:            Size            Action           

3. Roof Covering Type:            Size            Action           

Chimney:            Number of Fire Places           

Heating:            Type of Heat:           

Electrical:            Service Entrance Size:            Smoke Detector Required Yes            No           

Plumbing:            1. Approval of soil test if required Yes            No           

2. No. of Tubs or Showers           

3. No. of Flushes           

4. No. of Lavatories           

5. No. of Other Fixtures           

Swimming Pools:            Square Footage           

3. Minimum conform to National Electrical Code and State Law.

Signature of Applicant: Alan Duck

CEO's District: 6 Alan Duck

White - Tax Assessor

White - Tax Assessor

White - Tax Assessor

White - Tax Assessor

PERMIT ISSUED WITH LETTER

PERMIT ISSUED WITH LETTER

CONTINUED TO REVERSE SIDE

1-09 TAG CEO

16199 Row

8/28/92



**PLOT PLAN**



**FEES (Breakdown From Front)**

Base Fee \$ 60.00  
 Subdivision Fee \$ \_\_\_\_\_  
 Site Plan Review Fee \$ \_\_\_\_\_  
 Other Fees \$ \_\_\_\_\_  
 (Explain) \_\_\_\_\_  
 Late Fee \$ \_\_\_\_\_

**Inspection Record**

| Type                   | Date              |
|------------------------|-------------------|
| <i>Completed w/out</i> | <i>12.18.1971</i> |
| <i>inspected</i>       | <i>1.1.1972</i>   |
| <i>[Signature]</i>     | <i>1.1.1972</i>   |
|                        | <i>1.1.1972</i>   |

**COMMENTS** submitted 3 sheets of plans

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as has authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the code official or the code official's authorized representative shall have the authority to enter areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

*Alan Buck*  
 SIGNATURE OF APPLICANT

*75 Bridge St. Westbrook, Me.*  
 ADDRESS

*854-9688*  
 PHONE NO.

*Alan Buck ELDER*  
 RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

*(SAME)*  
 PHONE NO.

Inspection Services  
Samuel P. Hoffses  
Chief



Planning and Urban  
Joseph

CITY OF PORTLAND

October 6, 1992

RE: 355 Canco Road

Portland Congregation of Jehovah's Witness  
355 Canco Road  
Portland, ME 04103

Dear Sir:


Your application to construct storage facility has been reviewed and a permit is herewith issued subject to the following requirements:

No certificate of occupancy can be issued until all requirements of this letter are met.

1. Provide a portable fire extinguisher with at least a 40 BC rating.
2. Provide listed safety storage cabinets for all flammable or combustible liquids in excess of 10 gallons.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,



P. Samuel Hoffses  
Chief of Inspection Services

/el

cc: LT. Wallace Garroway, Fire Prevention Bureau