



# FIRE ALARM AND EMERGENCY COMMUNICATION SYSTEM RECORD OF COMPLETION

## 1. PROPERTY INFORMATION

Name of property: Roman Catholic Diocese  
Address: 510 Ocean Ave, Portland, ME  
Description of property: Office building  
Occupancy type: Business  
Name of property representative: Jimmy Somma  
Address: same  
Phone: 207-415-5220 Fax: E-mail:  
Authority having jurisdiction over this property: Portland FD  
Phone: Fax: E-mail:

## 2. INSTALLATION, SERVICE, AND TESTING CONTRACTOR INFORMATION

Installation contractor for this equipment: Protection One  
Address: 10 Manuel Dr Portland, ME 04103  
License or certification number: MC60018702  
Phone: 207-347-5300 Fax: 207-772-7355 E-mail:  
Service organization for this equipment: same  
Address:  
License or certification number:  
Phone: Fax: E-mail:  
A contract for test and inspection in accordance with NFPA standards is in effect as of: Oct 2015  
Contracted testing company: Same  
Address:  
Phone: Fax: E-mail:  
Contract expires: Oct 2020 Contract number: Frequency of routine inspections: Annual

## 3. DESCRIPTION OF SYSTEM OR SERVICE

- Fire alarm system (nonvoice)
- Fire alarm with in-building fire emergency voice alarm communication system (EVACS)
- Mass notification system (MNS)
- Combination system, with the following components:
  - Fire alarm
  - EVACS
  - MNS
  - Two-way, in-building, emergency communication system
- Other (specify):

**3. DESCRIPTION OF SYSTEM OR SERVICE (continued)**

NFPA 72 edition: 2010

Additional description of system(s): City of Portland Guidelines

**3.1 Control Unit**

Manufacturer: Firelite

Model number: MS9200UDLS

**3.2 Mass Notification System**

This system does not incorporate an MNS

**3.2.1 System Type:**

In-building MNS—combination

In-building MNS—stand-alone

Wide-area MNS

Distributed recipient MNS

Other (specify):

**3.2.2 System Features:**

Combination fire alarm/MNS

MNS autonomous control unit

Wide-area MNS to regional national alerting interface

Local operating console (LOC)

Direct recipient MNS (DRMNS)

Wide-area MNS to DRMNS interface

Wide-area MNS to high-power speaker array (HPSA) interface

In-building MNS to wide-area MNS interface

Other (specify):

**3.3 System Documentation**

An owner's manual, a copy of the manufacturer's instructions, a written sequence of operation, and a copy of the numbered record drawings are stored on site. Location: Doc Box

**3.4 System Software**

This system does not have alterable site-specific software.

Operating system (executive) software revision level:

Site-specific software revision date:

Revision completed by:

A copy of the site-specific software is stored on site. Location:

**3.5 Off-Premises Signal Transmission**

This system does not have off-premises transmission.

Name of organization receiving alarm signals with phone numbers:

Alarm: Protection 1

Phone: 800-438-4357

Supervisory: same

Phone:

Trouble: same

Phone:

Entity to which alarms are retransmitted: Portland Dispatch

Phone:

Method of retransmission: POTS ringdown

If Chapter 26, specify the means of transmission from the protected premises to the supervising station:

DACT dual line

If Chapter 27, specify the type of auxiliary alarm system:  Local energy  Shunt  Wired  Wireless

## 4. CIRCUITS AND PATHWAYS

### 4.1 Signaling Line Pathways

#### 4.1.1 Pathways Class Designations and Survivability

Pathways class: B Survivability level: 0 Quantity: 1  
(See NFPA 72, Sections 12.3 and 12.4)

#### 4.1.2 Pathways Utilizing Two or More Media

Quantity: 0 Description:

#### 4.1.3 Device Power Pathways

- No separate power pathways from the signaling line pathway
- Power pathways are separate but of the same pathway classification as the signaling line pathway
- Power pathways are separate and different classification from the signaling line pathway

#### 4.1.4 Isolation Modules

Quantity: 0

### 4.2 Alarm Initiating Device Pathways

#### 4.2.1 Pathways Class Designations and Survivability

Pathways class: Survivability level: 0 Quantity: 0  
(See NFPA 72, Sections 12.3 and 12.4)

#### 4.2.2 Pathways Utilizing Two or More Media

Quantity: Description:

#### 4.2.3 Device Power Pathways

- No separate power pathways from the initiating device pathway
- Power pathways are separate but of the same pathway classification as the initiating device pathway
- Power pathways are separate and different classification from the initiating device pathway

### 4.3 Non-Voice Audible System Pathways

#### 4.3.1 Pathways Class Designations and Survivability

Pathways class: B Survivability level: 0 Quantity: 4  
(See NFPA 72, Sections 12.3 and 12.4)

#### 4.3.2 Pathways Utilizing Two or More Media

Quantity: 0 Description:

#### 4.3.3 Device Power Pathways

- No separate power pathways from the notification appliance pathway
- Power pathways are separate but of the same pathway classification as the notification appliance pathway
- Power pathways are separate and different classification from the notification appliance pathway

**5. ALARM INITIATING DEVICES**

**5.1 Manual Initiating Devices**

**5.1.1 Manual Fire Alarm Boxes**

This system does not have manual fire alarm boxes.

Type and number of devices: Addressable: 11 Conventional: Coded: Transmitter:

Other (specify):

**5.1.2 Other Alarm Boxes**

This system does not have other alarm boxes.

Description:

Type and number of devices: Addressable: Conventional: Coded: Transmitter:

Other (specify):

**5.2 Automatic Initiating Devices**

**5.2.1 Smoke Detectors**

This system does not have smoke detectors.

Type and number of devices: Addressable: 20 Conventional:

Other (specify):

Type of coverage:  Complete area  Partial area  Nonrequired partial area

Other (specify):

Type of smoke detector sensing technology:  Ionization  Photoelectric  Multicriteria  Aspirating  Beam

Other (specify):

**5.2.2 Duct Smoke Detectors**

This system does not have alarm-causing duct smoke detectors.

Type and number of devices: Addressable: Conventional:

Other (specify):

Type of coverage:

Type of smoke detector sensing technology:  Ionization  Photoelectric  Aspirating  Beam

**5.2.3 Radiant Energy (Flame) Detectors**

This system does not have radiant energy detectors.

Type and number of devices: Addressable: Conventional:

Other (specify):

Type of coverage:

**5.2.4 Gas Detectors**

This system does not have gas detectors.

Type of detector(s):

Number of devices: Addressable: Conventional:

Type of coverage:

**5.2.5 Heat Detectors**

This system does not have heat detectors.

Type and number of devices: Addressable: 2 Conventional:

Type of coverage:  Complete area  Partial area  Nonrequired partial area  Linear  Spot

Type of heat detector sensing technology:  Fixed temperature  Rate-of-rise  Rate compensated

**5. ALARM INITIATING DEVICES (continued)**

**5.2.6 Addressable Monitoring Modules**

This system does not have monitoring modules.

Number of devices:

**5.2.7 Waterflow Alarm Devices**

This system does not have waterflow alarm devices.

Type and number of devices: Addressable: Conventional: Coded: Transmitter:

**5.2.8 Alarm Verification**

This system does not incorporate alarm verification.

Number of devices subject to alarm verification: Alarm verification set for: seconds

**5.2.9 Presignal**

This system does not incorporate pre-signal.

Number of devices subject to presignal:

Describe presignal functions:

**5.2.10 Positive Alarm Sequence (PAS)**

This system does not incorporate PAS.

Describe PAS:

**5.2.11 Other Initiating Devices**

This system does not have other initiating devices.

Describe:

**6. SUPERVISORY SIGNAL-INITIATING DEVICES**

**6.1 Sprinkler System Supervisory Devices**

This system does not have sprinkler supervisory devices.

Type and number of devices: Addressable: Conventional: Coded: Transmitter:

Other (specify):

**6.2 Fire Pump Description and Supervisory Devices**

This system does not have a fire pump.

Type fire pump:  Electric pump  Engine

Type and number of devices: Addressable: Conventional: Coded: Transmitter:

Other (specify):

**6.2.1 Fire Pump Functions Supervised**

Power  Running  Phase reversal  Selector switch not in auto  Engine or control panel trouble  Low fuel

Other (specify):

**6.3 Duct Smoke Detectors (DSDs)**

This system does not have DSDs causing supervisory signals.

Type and number of devices: Addressable: Conventional:

Other (specify):

Type of coverage:

Type of smoke detector sensing technology:  Ionization  Photoelectric  Aspirating  Beam

**6.4 Other Supervisory Devices**

This system does not have other supervisory devices.

Describe:

**7. MONITORED SYSTEMS**

**7.1 Engine-Driven Generator**

This system does not have a generator.

**7.1.1 Generator Functions Supervised**

- Engine or control panel trouble     Generator running     Selector switch not in auto     Low fuel  
 Other (specify):

**7.2 Special Hazard Suppression Systems**

This system does not monitor special hazard systems.

Description of special hazard system(s):

**7.3 Other Monitoring Systems**

This system does not monitor other systems.

Description of special hazard system(s):

**8. ANNUNCIATORS**

This system does not have annunciators.

**8.1 Location and Description of Annunciators**

Location 1:    FACP  
Location 2:    Front Entry  
Location 3:

**9. ALARM NOTIFICATION APPLIANCES**

**9.1 In-Building Fire Emergency Voice Alarm Communication System**

This system does not have an EVACS.

Number of single voice alarm channels:                      Number of multiple voice alarm channels:  
Number of speakers:    Number of speaker circuits:

Location of amplification and sound-processing equipment:

Location of paging microphone stations:

Location 1:

Location 2:

Location 3:

**9.2 Nonvoice Notification Appliances**

This system does not have nonvoice notification appliances.

Horns:    15                      With visible:    15                      Bells:                      With visible:

Chimes:                      With visible:

Visible only:    11                      Other (describe):

**9.3 Notification Appliance Power Extender Panels**

This system does not have power extender panels.

Quantity:

Locations:

**10. MASS NOTIFICATION CONTROLS, APPLIANCES, AND CIRCUITS**  This system does not have an MNS.

**10.1 MNS Local Operating Consoles**

Location 1:

Location 2:

Location 3:

**10.2 High-Power Speaker Arrays**

Number of HPSA speaker initiation zones:

Location 1:

Location 2:

Location 3:

**10.3 Mass Notification Devices**

Combination fire alarm/MNS visible appliances:

MNS-only visible appliances:

Textual signs:

Other (describe):

Supervision class:

**10.3.1 Special Hazard Notification**

This system does not have special suppression predischage notification.

MNS systems DO NOT override notification appliances required to provide special suppression predischage notification.

**11. TWO-WAY EMERGENCY COMMUNICATION SYSTEMS**

**11.1 Telephone System**

This system does not have a two-way telephone system.

Number of telephone jacks installed:

Number of warden stations installed:

Number of telephone handsets stored on site:

Type of telephone system installed:  Electrically powered  Sound powered

**11.2 Two-Way Radio Communications Enhancement System**

This system does not have a two-way radio communications enhancement system.

Percentage of area covered by two-way radio service: Critical areas: % General building areas: %

Amplification component locations:

Inbound signal strength: dBm Outbound signal strength: dBm

Donor antenna isolation is: dB above the signal booster gain

Radio frequencies covered:

Radio system monitor panel location:

**11. TWO-WAY EMERGENCY COMMUNICATION SYSTEMS (continued)**

**11.3 Area of Refuge (Area of Rescue Assistance) Emergency Communications Systems**

This system does not have an area of refuge (area of rescue assistance) emergency communications system.

Number of stations: \_\_\_\_\_ Location of central control point: \_\_\_\_\_

Days and hours when central control point is attended: \_\_\_\_\_

Location of alternate control point: \_\_\_\_\_

Days and hours when alternate control point is attended: \_\_\_\_\_

**11.4 Elevator Emergency Communications Systems**

This system does not have an elevator emergency communications system.

Number of elevators with stations: \_\_\_\_\_ Location of central control point: \_\_\_\_\_

Days and hours when central control point is attended: \_\_\_\_\_

Location of alternate control point: \_\_\_\_\_

Days and hours when alternate control point is attended: \_\_\_\_\_

**11.5 Other Two-Way Communication Systems**

Describe: \_\_\_\_\_

**12. CONTROL FUNCTIONS**

This system activates the following control functions:

- Hold-open door releasing devices    Smoke management    HVAC shutdown    F/S dampers
- Door unlocking    Elevator recall    Fuel source shutdown    Extinguishing agent release
- Elevator shunt trip    Mass notification system override of fire alarm notification appliances

Other (specify): \_\_\_\_\_

**12.1 Addressable Control Modules**

This system does not have control modules.

Number of devices: \_\_\_\_\_

Other (specify): \_\_\_\_\_

**13. SYSTEM POWER**

**13.1 Control Unit**

**13.1.1 Primary Power**

Input voltage of control panel: 120vac      Control panel amps: 5

Overcurrent protection:    Type: breaker      Amps: 20

Location (of primary supply panel board): closet across from breakroom

Disconnecting means location:    ckt 25

**13.1.2 Engine-Driven Generator**

This system does not have a generator.

Location of generator: \_\_\_\_\_

Location of fuel storage: \_\_\_\_\_

Type of fuel: \_\_\_\_\_



**13. SYSTEM POWER (continued)**

**13.1.3 Uninterruptible Power System**

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

**13.1.4 Batteries**

Location: FACP Type: SLA Nominal voltage: 24vdc Amp/hour rating: 12Ah

Calculated capacity of batteries to drive the system:

In standby mode (hours): 25

In alarm mode (minutes): 5

Batteries are marked with date of manufacture  Battery calculations are attached

**13.2 In-Building Fire Emergency Voice Alarm Communication System or Mass Notification System**

This system does not have an EVACS or MNS system.

**13.2.1 Primary Power**

Input voltage of EVACS or MNS panel:

EVACS or MNS panel amps:

Overcurrent protection: Type:

Amps:

Location (of primary supply panel board):

Disconnecting means location:

**13.2.2 Engine-Driven Generator**

This system does not have a generator.

Location of generator:

Location of fuel storage:

Type of fuel:

**13.2.3 Uninterruptible Power System**

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

**13.2.4 Batteries**

Location: Type: Nominal voltage: Amp/hour rating:

Calculated capacity of batteries to drive the system:

In standby mode (hours):

In alarm mode (minutes):

Batteries are marked with date of manufacture  Battery calculations are attached

**13. SYSTEM POWER (continued)**

**13.3 Notification Appliance Power Extender Panels**

This system does not have power extender panels.

**13.3.1 Primary Power**

Input voltage of power extender panel(s):

Power extender panel amps:

Overcurrent protection: Type:

Amps:

Location (of primary supply panel board):

Disconnecting means location:

**13.3.2 Engine-Driven Generator**

This system does not have a generator.

Location of generator:

Location of fuel storage:

Type of fuel:

**13.3.3 Uninterruptible Power System**

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

**13.3.4 Batteries**

Location:

Type:

Nominal voltage:

Amp/hour rating:

Calculated capacity of batteries to drive the system:

In standby mode (hours):

In alarm mode (minutes):

Batteries are marked with date of manufacture

Battery calculations are attached

**14. RECORD OF SYSTEM INSTALLATION**

*Fill out after all installation is complete and wiring has been checked for opens, shorts, ground faults, and improper branching, but before conducting operational acceptance tests.*

This is a:  New system     Modification to an existing system    Permit number:

The system has been installed in accordance with the following requirements: (Note any or all that apply.)

NFPA 72, Edition: 2010

NFPA 70, National Electrical Code, Article 760, Edition:

Manufacturer's published instructions

Other (specify): City of Portland Guidelines 2015

System deviations from referenced NFPA standards:

Signed:

Printed name: John Campbell ET

Date: 2-4-16

Organization: Protection 1

Title: Lead Commercial Installer

Phone: 207-347-5322

## 15. RECORD OF SYSTEM OPERATIONAL ACCEPTANCE TEST

New system

*All operational features and functions of this system were tested by, or in the presence of, the signer shown below, on the date shown below, and were found to be operating properly in accordance with the requirements for the following:*

Modifications to an existing system

*All newly modified operational features and functions of the system were tested by, or in the presence of, the signer shown below, on the date shown below, and were found to be operating properly in accordance with the requirements of the following:*

NFPA 72, Edition: 2010

NFPA 70, National Electrical Code, Article 760, Edition:

Manufacturer's published instructions

Other (specify):


Individual device testing documentation [Inspection and Testing Form (Figure 14.6.2.4) is attached]

Signed: \_\_\_\_\_ Printed name: John Campbell ET Date: 2-4-16  
Organization: Protection 1 Title: Lead Commercial Installer Phone: 207-347-5322

## 16. CERTIFICATIONS AND APPROVALS


### 16.1 System Installation Contractor:

This system, as specified herein, has been installed and tested according to all NFPA standards cited herein.

Signed:  Printed name: John Campbell ET Date: 2-4-16  
Organization: Protection 1 Title: Lead Commercial Installer Phone: 207-347-5322


### 16.2 System Service Contractor:

The undersigned has a service contract for this system in effect as of the date shown below.

Signed:  Printed name: John Campbell ET Date: 2-4-16  
Organization: Protection 1 Title: Lead Commercial Installer Phone: 207-347-5322

### 16.3 Supervising Station:

This system, as specified herein, will be monitored according to all NFPA standards cited herein.

Signed:  Printed name: John Campbell ET Date: 2-4-16  
Organization: Protection 1 Title: Lead Commercial Installer Phone: 207-347-5322

**16. CERTIFICATIONS AND APPROVALS (continued)**

**16.4 Property or Owner Representative:**

This system, as specified herein, will be monitored according to all NFPA standards cited herein.

Signed: \_\_\_\_\_ Printed name: \_\_\_\_\_ Date: \_\_\_\_\_  
Organization: \_\_\_\_\_ Title: \_\_\_\_\_ Phone: \_\_\_\_\_

**16.5 Authority Having Jurisdiction:**

I have witnessed a satisfactory acceptance test of this system and find it to be installed and operating properly in accordance with its approved plans and specifications, with its approved sequence of operations, and with all NFPA standards cited herein.

Signed: \_\_\_\_\_ Printed name: \_\_\_\_\_ Date: \_\_\_\_\_  
Organization: \_\_\_\_\_ Title: \_\_\_\_\_ Phone: \_\_\_\_\_