Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 12/23/15

Fire Alarm System

510 Ocean Avenue, Portland, Maine 04102

SCOPE of WORK: The submittal for this permit is to upgrade and enhance the existing fire alarm system for the building located at 510 Ocean Avenue. The system will be installed as indicated by the design layout file LS1 Life Safety Plan 1st Level and LS2 Life Safety Plan 2nd Level Fire Alarm Drawings. The installation will happening soon after the approval. The existing system is a conventional fire with very limited initiation and occupant notification. The new system will have manual initiation at exits and stairwells; common area automatic initiation and occupant notification.

The system has the following features

- Addressable control panel
- LED Annunciator located at the front entrance 1st level
- Addressable initiation devices (including manual and automatic initiation)
- Occupant notification devices