Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 12/23/15

Protection 1 Branch 11660
10 Manual Drive, Portland, ME 04103 PH# 1-800-310-5011

System Outputs: Control Unit Annunciation | Notification | Safety Control

System Inputs	Actuate common alarm signal indicator	Actuate audible alarm system	Actuate common supervisory signal indicator	Actuate audible supervisory signal	Actuate common trouble signal indicator	Actuate 1st Floor Evacuation Signals	Actuate 2nd Floor Evacuation Signal	Transmit fire alarm signal to supervising station	Transmit supervisory signal to supervising	Transmit trouble signal to supervising station
System Pull Stations	X	X				X	X			X
System Smoke Detectors	X	X				X	X			X
System Heat Detectors	X	X				X	X			X
System Duct Smoke Detectors	X	X				X	X			X
FACP AC Loss				X	X				X	
FACP Low Battery				X	X				X	
FACP Ground Fault				X	X				X	
Phone Line #1 Fail				X	X				X	
Phone Line #2 Fail				X	X				X	

Roman Catholic Diocese
510 Ocean Avenue
Portland, Maine 04102