

## A Brand of Heatcraft Refrigeration Products 2175 West Park Place Boulevard

2175 West Park Place Boulevard Stone Mountain, GA 30087 800.537.7775 www.larkinproducts.com

# LHS030X6C

Hermetic Air-cooled


Project:	QUOTATION:	JG20120928152740;0 Item No: 1
Location: ,	Submitted by:	John Gibson
Customer:	DATE:	9/28/2012
Identity #:		Ву:
Tag:	☐ For Approval	Date:

## PHYSICAL & ELECTRICAL DATA

REFRIGERANT	COMPRESSO	)R		CONNECTIONS (inches)		NET WEIGHT	SOUND DATA	ALTITUDE	AMBIENT TEMP
	Model No.	HP	Liquid	Suction					
R404A/R507	CS18K6E	3	1/2	7/8	20	303	73	0	95°F

POWER SUPPLY	COMP	RESSOR	FAI	TOM V	OR	М	CA†	М	OP‡	Evap. Fan	Defrost Heater
Volts / Ph / Hz	RLA	LRA	QTY	HP	FLA	Air	Elec.	Air	Elec.	Amps	Amps
208-230/3/60	9.4	65.5	1	1/3	3.5	15		20			

†MCA=Minimum Circuit Ampacity ‡MOP = Maximum Overcurrent Protection



			DIMENS	IONS (incl	nes)			
Α	В	С	D	Е	F	G	Η	J
30 1/4	42 1/2	29 3/4	2 1/16	2 5/8	4 9/16	2 9/16	23 1/8	43

	DIMENSIONS (inches)					
K	L	М	Ν	Р	R	S



2175 West Park Place Boulevard Stone Mountain, GA 30087 800.537.7775 www.larkinproducts.com

## LHS030X6C

Hermetic Air-cooled

Project:	QUOTATION:	JG20120928152740;0 Item No: 1
Location: ,	Submitted by:	John Gibson
Customer:	DATE:	9/28/2012
Identity #:		Ву:
Tag:	☐ For Approval	Date:

# 3 1/4 3 13/16 4 15/16 5 1/4 1 15/16 2 1/4 3 11/16

		(	CAPACITY (BTUH	)		
40 °F SST	35°F SST	30 °F SST	25 °F SST	20 °F SST	15 °F SST	10°F SST
0	0	27840	25490	23130	20720	18310

			CAPACITY (BTUH	)		
5 °F SST	0 °F SST	-5 °F SST	-10 °F SST	-15 °F SST	-20 °F SST	-25 °F SST
15890	13480	11600	9710	8230	6750	5620

		C	CAPACITY (BTUH)			
-30 °F SST	-30 °F SST -35 °F SST -40 °F SST					
0	0	0				

SST = Saturated Suction Temperature

### STANDARD FEATURES

Cabinet & Construction

- · Painted steel cabinets with outdoor weather hood
- Heavy duty steel raised base with 1-1/2" legs
- Suction service valves for hermetic and scroll compressors located outside the cabinet
- Semi-hermetic compressor models have a suction valve on the compressor and an access fitting on the suction line entering the cabinet
- · Receiver with fusible plug, liquid shutoff valve and charging port
- Large electrical panel
- · Prefabricated wiring harnesses
- Sight glass/moisture indicator
- Piping is pre-bent to eliminate leaks
- Head pressure control valve
- · Ambient temperature sensor

#### Coil

- HyperCore™ microchannel coil technology
- Completely leak tested in a helium environment

- Compressor
- Hermetic, semi-hermetic and scroll. R-22 and R-404A/507 available for both medium and low temperature applications
- Spring-mounted compressors with vibration eliminators on all 1-1/2 to 6 HP semi-hermetic compressors; 1/2 to 1 HP compressors are rigid mounted and have a discharge loop
- Discharge service valves
- Crankcase Heater
- 24 volt compressor control circuit
- Service switch
- Bump tested and allowed to cycle off on the high and low pressure control
- Encapsulated, auto-reset, high and low pressure controls (adjustable low pressure control on low temperature models)

### Fan Motors:

- Rated for 50 and 60 cycle application
- Standard PSC fan motors
- Specifically matched fans with motor and coil
- Fan Cycling (on 2 fan units)



2175 West Park Place Boulevard Stone Mountain, GA 30087 800.537.7775 www.larkinproducts.com

# LHS030X6C

Hermetic Air-cooled


Project:	QUOTATION:	JG20120928152740;0 Item No: 1
Location: ,	Submitted by:	John Gibson
Customer:	DATE:	9/28/2012
Identity #:		By:
Tag:	☐ For Approval	Date:

## **OPTIONS**

1	Mai	ını	ha	On	tio	ns:
- 1	viOi	unu	eu	UL	ılıu	1115.

Olda Lassas Outland	
Ship Loose Options:	
None	

### MINIMUM UNIT CLEARANCES





## A Brand of Heatcraft Refrigeration Products 2175 West Park Place Boulevard

2175 West Park Place Boulevard Stone Mountain, GA 30087 800.537.7775 www.larkinproducts.com

# **LCA6110BB**


Low Profile Walk-in

Project:	QUOTATION:	JG20120928152740;0 Item No: 1
Location: ,	Submitted by:	John Gibson
Customer:	DATE:	9/28/2012
Identity #:		By:
Tag:	☐ For Approval	Date:

## PHYSICAL & ELECTRICAL DATA

DEFROST TYPE	AIR FLOW	VOLTAGE	CAPACITY	RATING TD	RATING SST	Approx. NET WEIGHT	ALTITUDE
Air	1300	208- 230/1/60	11000	10	23	48	0

FANS			HEA	TERS	CONNECTIONS (inches)				
QT	Υ	FLA	MOTOR TYPE	BLADE	AMPS	WATTS	INLET	OUTLET	DRAIN
2	2	1	EC	12.0			1/2	7/8	3/4



DIMENSIONS (inches)											
Α	В	С	D	Е	F	G	Н	J	K	L	М
45.50	12.00	14.94	2.88	4.19	1.75	12.38	1.06	3.00	22.75	18.00	13.44

DIMENSIONS (inches)									
	Ν	Р	R	S	Т	U	V	Х	Υ



2175 West Park Place Boulevard Stone Mountain, GA 30087 800.537.7775 www.larkinproducts.com

## **LCA6110BB**

Low Profile Walk-in

Project:	QUOTATION:	JG20120928152740;0 Item No: 1
Location: ,	Submitted by:	John Gibson
Customer:	DATE:	9/28/2012
Identity #:		Ву:
Tag:	☐ For Approval	Date:

6.13 | 33.25 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00

### STANDARD FEATURES

### Cabinet

- Attractive white painted aluminum cabinet
- Front Access to electrical and refrigeration components
- Small, low profile physical cabinet size with optimized interior space
- The electrical board is front facing for easy access
- Internal panels are isolated for quiet operation
- Beacon II™ microprocessor mounted in piping section
- Thermistor temperature sensors factory mounted

(suction line, coil end plate, and entering air stream)

- Refrigerant distributor nozzle is factory mounted
- Electric expansion valve factory mounted
- · Suction pressure transducer factory mounted
- 24V control circuit transformer factory mounted

#### Drain Pan:

 Drain fitting is located to the back of the unit with larger diameter

### Coil:

- Internally enhanced copper tubing and aluminum fin design for higher efficiency
- Schrader valve on suction header
- · Sweat connections to reduce potential for leaks

Fan Guards and Motors:

- Improved plastic, round guard design
- Motor harness and solenoid harness are at the bottom of the unit for easy access
- · Motor harness easily plugs in
- EC motors available factory-installed

OPTI	ONS
------	-----

	Mounted Options:	
	Ship Loose Options (by Unit):	
Γ	None	
	Ship Loose Options (by System):	
Γ	None	

**MINIMUM UNIT CLEARANCES** 





2175 West Park Place Boulevard Stone Mountain, GA 30087 800.537.7775 www.larkinproducts.com

# **LCA6110BB**

Low Profile Walk-in

Project:	QUOTATION:	JG20120928152740;0 Item No: 1
Location: ,	Submitted by:	John Gibson
Customer:	DATE:	9/28/2012
Identity #:		By:
Tag:	☐ For Approval	Date:





Two evaporators