DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

V S H REALTY INC /Pro Signs

Located at

801 WASHINGTON AVE

PERMIT ID: 2013-01342

ISSUE DATE: 08/26/2013

163 B003001 CBL:

has permission to replace existing free standing sign - remove 30 sf round Gulf Sign - new sign 20' tall & 6' x 8' - replace building sign & two new canopy signs - 12.38 sf each

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Gas Dispensing & Retail

PERMIT ID: 2013-01342

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

CBL: 163 B003001

Located at: 801 WASHINGTON AVE

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

 City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 2013-01342

Date Applied For: 06/27/2013

CBL:

163 B003001

Proposed Use:

Cumberland Farms - gas station & convenience store

Proposed Project Description:

replace existing free standing sign - remove 30 sf round Gulf Sign new sign 20' tall & 6' x 8' - replace building sign & two new canop signs - 12.38 sf each

Dept: Zoning Status

Status: Approved w/Conditions

Reviewer: Marge Schmuckal

Approval Date:

08/26/2013

Ok to Issue:

Note: B-2 Zone - Gas Stations

Fre standing Sign

max sf - 79 sf - 48 sf - proposed -OK max ht. - 18' - was 26' - propsoed 20' OK

Canopy Signs

2 allowed at opposite ends - OK max. sf 20 st - 12.38 sf propsoed - OK

Building Sign

1 sign for each major activity - 2 proposed

max sf - 30 sf for principal sign - 27.8 sf for front; 16.75 for side

max ht. - 2' - 4'8" proposed

8/12/13 Appealing size (height of letters) of building sign to planning under section 14-368.5(g).

Conditions:

1) Approved with the condition that the Planning review conditions be met in full.

Dept: Planning

Status: Approved w/Conditions

Reviewer: Shukria Wiar

Approval Date:

08/19/2013

Ok to Issue:

Note: Conditions:

1) Approved but the condition that there be no building sign proposed along the Ocean Aveenue street side.