

CITY OF PORTLAND  
 FIRE PREVENTION BUREAU  
 380 Congress Street, Portland, Maine 04101  
 fireprevention@portlandmaine.gov  
 (207) 874-8400

**NOTICE OF VIOLATION AND ORDER TO CORRECT**

November 10, 2016

|   |   |                                     |
|---|---|-------------------------------------|
| <b>Responsible Party 1:</b><br>Johnson Scott<br>493 OCEAN AVE<br>PORTLAND, ME 04103 |   |                                     |
| <b>Location</b><br>493 OCEAN AVE  | <b>CBL</b><br>163 D003001                       | <b>Inspection Date</b><br>11/7/2016 |
| <b>Inspector</b><br>Mark Stewart  | <b>Inspection Type</b><br>FP Routine Inspection | <b>Status</b><br>Failed             |

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must complete the proposed date of completion column by proposing a reasonable timeframe to remedy each violation. This form must be received by the Fire Prevention Bureau no later than 11/30/2016. The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

**YOUR FAILURE TO SUBMIT A PLAN OF ACTION BY THE DATE PROVIDED, OR TO CORRECT ANY VIOLATION WITHIN THE APPLICABLE TIME FRAME, MAY RESULT IN LEGAL ACTION AGAINST YOU, THE IMPOSITION OF CIVIL PENALTIES, AND THE PURSUIT OF OTHER LEGAL REMEDIES.**

| Violation  | Proposed Date of Completion  |
|--|--|
| ① <b>NFPA 101- 31.3.3.2 INTERIOR FINISH;</b> Interior wall and ceiling finish materials complying with 10.2 shall be permitted as follows: (1) Exit enclosures- Class A or B (2) Lobbies and corridors- Class A or B (3) Other Spaces- Class A, B, or C.<br>Paneling in rear stairway. | 2 / 1 / 17   |
| ② <b>NFPA 1 EXCESSIVE/DISORDERLY STORAGE;</b> Reference NFPA 1 for excessive fuel-load.<br>Dust and wood scrap clutter and debris in basement as well as general housekeeping/organization. Storage in front and back Stair/Hallways.  | 3 / 1 / 17   |
| ③ <b>NFPA 30- TABLE 9.6.2.1 FLAMMABLE/COMBUSTIBLE LIQUIDS STORAGE EXCEED LIMIT;</b> See NFPA 30 Table 9.6.2.1 for special occupancy limits for flammable and combustible liquid storage.<br>Flammable Liquids storage cabinet needed for Oil-based paints, finishes and solvents.      | IMMEDIATELY remove all excess flammable/combustible material from the interior of the structure. Your signature below indicates that all excess material has been removed, will not be replaced, and will be properly disposed of or stored elsewhere. |
| ④ <b>NFPA 70 MISSING COVER ON PANEL;</b> Refer to NFPA 70, National Electrical Code, on requirements of missing cover on electrical panel.<br>Electrical Panel cover needs to be re-installed.   | 11 / 20 / 16<br>S.W. [Signature]   |

*Done 11/30/16*

| Violation   | Proposed Date of Completion           |
|---|---------------------------------------|
| 5) <b>NFPA 101- 31.3.2.1.1 BOILER PROTECTION REQUIRED;</b> The areas described in Table 31.3.2.1.1 shall be protected as indicated: Boiler and fuel-fired heater rooms serving more than a single dwelling unit (minimum separation/protection is 1 hour or sprinklers)<br>Sprinkler needed over wall mounted on-demand water heater. | 12 / 30 / 16                          |
| 6) <b>NFPA 1, CHAPTER 10 - 10.11.6 HIBACHI OR GRILL ON BALCONY; NO HIBACHI, GAS-FIRED GRILL, CHARCOAL GRILL, OR OTHER SIMILAR DEVICES USED FOR COOKING, HEATING, OR OTHER PURPOSE, SHALL BE USED OR KINDLED ON ANY BALCONY OR UNDER ANY OVERHANG PORTION OR WITHIN 10 FT OF ANY STRUCTURE</b><br>Gas Grill on third floor deck.       | 11 / 20 / 16<br>Complete 11 / 25 / 16 |
| 7) <b>NFPA 101- 8.3.4.2 60 MINUTE FIRE DOOR REQUIRED;</b> Refer to NFPA 101- Table 8.3.4.2 that states fire door assemblies for vertical shafts (including stairways, exits, and refuse chutes) are rated and required for 1 hour.<br>Fire Doors needed.  | 12 / 30 / 16                          |

**VIOLATOR CERTIFICATION**

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

11/27/16 \_\_\_\_\_  
 Date Responsible Party  
*Small John*

\_\_\_\_\_  
 Date Responsible Party

**SEEN AND AGREED**

\_\_\_\_\_  
 Date Fire Prevention Bureau