FLOOR PLAN

20 LYNdA Rd.

PROPOSCD

CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/15/14

Please clarify renovations being do
If bedroom is being added, provide egress window
per R310. Clarify spacing and dimensions of
bathroom and spell out minimum fixture clearances
per Figure R307.1. Clarify if there are hazardous
conditions per R308.4.

4'X7' AREA will be Added To EXISTING CNclosed PORCh
AND RENOVATED INTO BedROOM AND BATh
AN EGRESS WINDOW will be INSTALLED IN The bedROOM

SCALE 1"=10'