

Inspection Services  
Michael J. Nugent  
Manager

Department of Urban Development  
Joseph E. Gray, Jr.  
Director



## CITY OF PORTLAND

October 27, 1999

Spurwink School  
K. C. MacArthur  
587 Ocean Avenue  
Portland, ME 04103

RE: Spurwink School FSE, CBL 163A-A-017

Dear Mr. MacArthur:

Please be advised per the Food Service Inspection on October 21, 1999 that the Spurwink School Food Service License will not be approved until the following code violation is rectified.

This is a notice of violation pursuant to Chapter 11 of the Portland Code of Ordinances. Specifically:

Sec. 11-28 Cleaning of the premises – hot water sanitation shall be at least (180) degrees Fahrenheit or use of appropriate chemical sanitation.

Sec. 11-27 Kitchen Equipment – new equipment shall bear the National Sanitation Foundation Seal of Approval or be of equivalent standard.

All referenced violations shall be corrected within 14 days of the date of this notice. Please notify this office for an inspection of the equipment when the corrections have been satisfied. Feel free to contact me at 874-8708, or 8715 if you wish to discuss this matter or have any questions.

Sincerely,

Kevin Carroll, Jeanie Bourke  
Code Enforcement Officers

Cc/Central File

