

GENERAL NOTES:

REVISIONS:

BENNETT ENGINEERING
 MECHANICAL/ELECTRICAL
 (207) 855-9475

FORESIDE ARCHITECTS
 LLC

5 Fundy Road
 Falmouth, Maine 04105
 Phone: 207-781-3344
 Fax: 207-699-5564

Online @ foresidearchitects.com

Project Status: Bid Set

Project Number: SR0712

Project Title: Seaside Rehab & Healthcare Center
 850 Baxter Blvd
 Portland, ME

Drawing Name: VRV System Equipment Schedule #1

Scale: 1/8"=1'-0"

Date: 10/29/12

SHEET

M1.5

Centralized Control 1

RoomName	Estimated Capacity for each room			Selected Model		Rated Capacity (By Indoor unit)		Calculated Actual Capacity on Design Tool (Total for room)				Current Input		Power Source		Design Condition				System			
	For Cooling (Total)	For Cooling (Sensible)	For Heating	Ref.	Model name	Cooling (Total)	Heating	Cooling (Total)	Cooling (Sensible)	Heating	Cooling (Sensible)	Heating	Coolant	Heating	Dry bulb temperature	Relative Humidity	Wet bulb temperature	Dry bulb temperature	Relative Humidity		Wet bulb temperature		
																						Cc	T
SAC-1	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-10	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-11	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-12	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-13	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-14	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-15	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-16	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-17	0	0	0		PLFY-P36NBMU-E	36000	40000	37447	18601	40168	37447	18601	40168	1.07	1.00	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-18	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-19	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-20	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-21	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-22	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-23	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-24	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-25	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-26	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-27	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-28	0	0	0		PLFY-P36NBMU-E	36000	40000	37447	18601	40168	37447	18601	40168	1.07	1.00	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-29	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-30	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-31	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-32	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-33	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-34	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-35	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-36	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-37	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-38	0	0	0		PLFY-P36NBMU-E	36000	40000	37447	18601	40168	37447	18601	40168	1.07	1.00	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-39	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-40	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-41	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-42	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-5	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-6	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-7	0	0	0		PLFY-P36NBMU-E	36000	40000	37447	18601	40168	37447	18601	40168	1.07	1.00	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-8	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1
SAC-9	0	0	0		PKFY-P08NBMU-E	8000	9000	8322	4366	9038	8322	4366	9038	0.15	0.15	208/230V	80.6	66	72.0	68.0	88.0	First Floor	1

Schedule is continued on Drawing M1.6.