

Paul R. LePage  
Governor



Maine Department of Public Safety  
State Fire Marshal's Office  
52 State House Station  
Augusta, ME 04333-0052



John E. Morris  
Commissioner

Phone: (207) 626-3880  
Fax: (207) 287-6251

Joseph E. Thomas  
State Fire Marshal

### Plans Review Summary

Project Name:	SEASIDE REHAB AND HEALTH CARE CENTER	Owner Name:	FIRST ATLANTIC CORP
Location:	850 BAXTER BLVD PORTLAND, ME 04103-4901	Mailing Address:	FIRST ATLANTIC CORP 100 WATERMAN DR SOUTH PORTLAND, ME 04106-2880
Pending Permit Number:	21164	Architect/Design Professional (If applicable):	MARK BURNS

Your drawings have been reviewed under the currently adopted NFPA 101 Life Safety Code and all referenced publications, as well as the Maine Human Rights Act. The following items were discovered during the review on your plan:

1. Provide documentation that sliding doors are ADA compliant.
2. New healthcare shall be subdivided. see Chapter 18/ 18.3.7

**These items need to be addressed before a permit can be issued.**

Date of Review: 1/7/2013  
Inspector: RONALD PEASLEE  
Date Sent: 1/14/2013

Reviewer Signature: