



PO Box 2551
2257 West Broadway
South Portland, ME 04106

1.800.370.3473
fax 207.879.0540

www.norrisinc.com

1/22/13

Scope of Work: Seaside Rehabilitation Addition

Regional Electric will be installing new addressable fire alarm devices to accommodate the new addition at Seaside Rehab. The contractor will also install a new addressable fire alarm panel as the existing panel does not have the capacity to add the quantity of devices required.

The addition will be fully sprinkled. There is currently a master box on site. Norris Inc. will be installing a new AES radio master box to meet current requirements. We are assuming a standard rubber ducky antennae will be sufficient, however if that is not the case an external antennae will be added.

Smoke detectors and carbon monoxide detectors in the patient rooms will be system connected. These are strictly patient rooms and there are no cooking facilities within them.

Norris Inc. will provide fire alarm equipment, submittal documents, fire alarm permits, final connections and testing per City of Portland requirements.