SYMBOL LEGEND

- FACP — FIRE ALARM CONTROL PANEL
- ANN — FIRE ALARM ANNUNCIATOR PANEL
- P15G — FIRE ALARM AUDIO/VISUAL, MOUNT 6'-8"AFF, NUMBER DENOTES CANDELA RATING. "MH" DENOTES MINIHORN, "CL" DENOTED CEILING MOUNTED. NO DESIGNATION EQUALS 15cd
- F — FIRE ALARM PULL STATION, MOUNT 48"AFF
- P15 SPI — FIRE ALARM VISUAL STROBE ONLY, FLUSH MOUNT 6'-8" AFF, NUMBER DENOTES CANDELA RATINGS. "CL" DENOTES CEILING MOUNTED
- 2G — SYSTEM CONNECTED SMOKE / CARBON MONOXIDE DETECTOR, PHOTOELECTRIC TYPE
- L135° — SYSTEM CONNECTED FIXED TEMPERATURE HEAT DETECTOR
- SD — SMOKE DETECTOR, PHOTOELECTRIC TYPE, SYSTEM CONNECTED.
- ER SD — SMOKE DETECTOR, PHOTOELECTRIC TYPE, SYSTEM CONNECTED. "ER" DENOTES ELEV RECALL
- SB SD — SYSTEM CONNECTED SMOKE DETECTOR, PHOTOELECTRIC TYPE, WITH SOUNDER BASE
- CO — CARBON MONOXIDE DETECTOR
- SD — DUCT SMOKE DETECTOR & TEST STATION

COPYRIGHT 2014
REUSE OR REPRODUCTION OF THE
THIS DOCUMENT IS NOT PERMITTE
WRITTEN PERMISSION OF FORESID

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

GENERAL NOTES Date: 03/30/15

REVISIONS:
.

BENNETT ENGINEERING
MECHANICAL • ELECTRICAL
(207) 865-9475

FORESIDE ARCHITECTS LLC
5 FUNDY ROAD
FALMOUTH, ME 04105
Phone: 207-781-3344
Fax: 207-699-5564
Online @ foresidearchitects.com

Project Status:
Permit and Bid Set

Project Number:
SRH0314

STATE OF MAINE STEVEN W. JOHNSON #8488 LICENSED PROFESSIONAL ENGINEER

Seaside Rehabilitation
and Healthcare Center
Lobby / Rehab Renovation
850 Baxter Boulevard
Portland, Maine

Drawing Name:
LOBBY FIRE ALARM PLAN

Scale:
1/8"=1'-0" OR
AS NOTED

Date:
02/18/2015

SHEET:
FA-1.1