Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 03/30/15

SYSTEM OUTPUTS

SYSTEM INPUTS		CONTROL UNIT ACTIVATION								NOTIFICATION					
		ACTUATE COMMON ALARM SIGNAL INDICATOR	ACTUATE AUDIBLE ALARM SIGNAL	ACTUATE COMMON SUPERVISORY SIGNAL INDICATOR	ACTUATE AUDIBLE SUPERVISORY SIGNAL	ACTUATE COMMON TROUBLE SIGNAL INDICATOR	ACTUATE AUDIBLE COMMON TROUBLE SIGNAL	DISPLAY ALPHA-NUMERIC SYSTEM STATUS MESSAGE	RECORD EVENTS IN THE SYSTEM MEMORY	ACTUATE GENERAL EVACUATION SIGNALS	TRANSMIT FIRE ALARM SIGNAL TO REMOTE ALARM RECEIVING STATION	TRANSMIT SUPERVISORY SIGNAL TO REMOTE ALARM RECEIVING STATION	TRANSMIT TROUBLE SIGNAL TO REMOTE ALARM RECEIVING STATION	RELEASE FIRE DOOR HOLDERS	
		A	B	C	D	E	F	G	H	I	J	K	L	M	
1	MANUAL FIRE ALARM PULL STATION	●	●					●	●	●	●			●	1
2	AREA SMOKE DETECTOR	●	●					●	●	●	●			●	2
3	FIRE ALARM AC POWER FAILURE					●	●	●	●				●		3
4	FIRE ALARM SYSTEM LOW BATTERY					●	●	●	●				●		4
5	OPEN CIRCUIT					●	●	●	●				●		5
6	GROUND FAULT					●	●	●	●				●		6
		A	B	C	D	E	F	G	H	I	J	K	L	M	

REVISION 2	DATE:	
REVISION 1	DATE:	
REVISION 0 SUBMITTAL	DATE:	11/25/2014
CAUSE AND EFFECT MATRIX		
PROJECT NAME **SEASIDE REHAB AND HEALTHCARE LOBBY RENOVATIONS** 850 BAXTER BOULEVARD PORTLAND, ME	SCALE NTS	
	BY: JRS	
	CK BY:	
NORRIS INC Prepared For Tomorrow; Delivered Today 2257 BROADWAY, So PORTLAND, MAINE	SAVED AS:	