NORRIS INC

PO Box 2551
2257 West Broadway
South Portland, ME 04106

1.800.370.3473
fax 207.879.0540

RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions

2/27/15

Date: 03/30/15

Scope of Work: Seaside Nursing Lobby Reno

Regional Electric is adding fire alarm devices for the lobby renovation. The devices will be added to the existing addressable Notifier fire alarm panel.

There is an existing master box on site.

Norris Inc. will program and test the renovated area according to City of Portland requirements.