

Craig Messinger - RE: 93-95 Illsley

From: Nathan Babb <nbabb@hotmail.com>
To: Craig Messinger <crm@portlandmaine.gov>
Date: 5/14/2015 4:26 PM
Subject: RE: 93-95 Illsley

Hi Craig,

Our plan of action will be to have this work done within one years time from today (5/14/2015). This includes replacing 8 doors with fire doors rated at 1 hour.

Thanks,

Nathan Babb

Date: Thu, 14 May 2015 16:21:53 -0400
From: crm@portlandmaine.gov
To: nbabb@hotmail.com
Subject: 93-95 Illsley

Sir,

Per our conversation, you have indicated that you are planning to upgrade your current apartment doors which are not code compliant, to doors which meet the 1 hour fire rating. We will not require you to upgrade the solid wood frames that currently exist in your building, only the doors and the self-closing hinges. Please submit a Plan of Action to our office for approval of your upgrades,

Respectfully,
Craig Messinger

380 Congress st
Portland Maine 04101
874-8400

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.