



. . . Fire Protection by Computer Design

FREEDOM FIRE PROTECTION INC.
209 QUAKER RIDGE ROAD
CASCO, MAINE 04015
207-627-4109

Job Name : BETHANY HOUSE PARISH HC2
Building : 10 ALTON STREET
Location : PORTLAND, MAINE 04103
System : #1 AREA #2
Contract :
Data File : BETHANY HOUSE PARISH HC2.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - BETHANY HOUSE PARISH OFFICE Date - 6/14/12
Location - PORTLAND, MAINE 04103
Building - 10 ALTON STREET System No. - #1 AREA #2
Contractor - FREEDOM FIRE PROTECTION Contract No. -
Calculated By - MICHAEL NOBLIT Drawing No. - FP-1
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-6"
OCCUPANCY - HOUSE

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 ()4 (X)3
S (X)Other MAINE LIFE SAFETY
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 14 Gpm System Type
Listed Pres. at Start Point - 10.1 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 14 x 14 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - 0 Gpm Make TYCO Model LFII
I Elevation at Highest Outlet - 16'-0"Feet Size 1/2" K-Factor 4.4
G Note: Temperature Rating 155
N

Calculation Gpm Required 43.195 Psi Required 46.110 At Test
Summary C-Factor Used: Overhead 120 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - Rated Cap. 50 Cap.
T Time of Test - @ Psi 50 Elev.
E Static (Psi) - Elev.
R Residual (Psi) - Other Well
Flow (Gpm) - Proof Flow Gpm
S Elevation -
P Location:
P
L Source of Information:
Y

Water Supply Curve (C)

FREEDOM FIRE PROTECTION INC.
BETHANY HOUSE PARISH HC2


Page 2
Date 6/14/12

Pump Data:

P1 - Pump Churn Pressure : 55
 P2 - Pump Rated Pressure : 50
 P2 - Pump Rated Flow : 50
 P3 - Pump Pressure @ Max Flow : 32.5
 P3 - Pump Max Flow : 75

Demand:

D1 - Elevation : 6.930
 D2 - System Flow : 43.1951
 D2 - System Pressure : 46.110
 Hose (Adj City) : _____
 Hose (Demand) : _____
 D3 - System Demand : 43.1951
 Safety Margin : 5.527



Fittings Used Summary

FREEDOM FIRE PROTECTION INC.
BETHANY HOUSE PARISH HC2

Page 3
Date 6/14/12

Fitting Legend																					
Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
S	Generic Swing Check Vlv	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION INC.
 BETHANY HOUSE PARISH HC2

Page 4
 Date 6/14/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
201	16.0	4.4	10.84	na	14.49	0.05	0.001	10.1
202	16.0	4.4	11.2	na	14.72	0.05	0.001	10.1
203	16.0	4.4	10.1	na	13.98	0.05	0.001	10.1
24	16.0		11.24	na				
23	16.0		16.96	na				
22	16.0		21.73	na				
21	16.0		28.54	na				
20	16.0		32.49	na				
4	6.66		38.31	na				
3	6.66		39.35	na				
2	6.66		40.86	na				
1	0.0		45.54	na				
TEST	0.0		46.11	na				

The maximum velocity is 16.04 and it occurs in the pipe between nodes 24 and 23

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION INC.
BETHANY HOUSE PARISH HC2

Page 5
Date 6/14/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
201 to 24	14.49	1.049 120	1T 5.0 0.0	0.500 5.000	10.841 0.0			K Factor = 4.40	
	14.49	0.0716	0.0	5.500	0.394			Vel = 5.38	
	0.0 14.49					11.235		K Factor = 4.32	
202 to 24	14.72	1.049 120	0.0 0.0	0.500 0.0	11.198 0.0			K Factor = 4.40	
	14.72	0.0740	0.0	0.500	0.037			Vel = 5.46	
	0.0 14.72					11.235		K Factor = 4.39	
203 to 24	13.98	1.049 120	3E 6.0 0.0	10.916 6.000	10.100 0.0			K Factor = 4.40	
	13.98	0.0671	0.0	16.916	1.135			Vel = 5.19	
24 to 23	29.22	1.049 120	1E 2.0 0.0	8.583 2.000	11.235 0.0				
	43.2	0.5409	0.0	10.583	5.724			Vel = 16.04	
23 to 22	0.0	1.049 120	2F 2.0 0.0	6.830 2.000	16.959 0.0				
	43.2	0.5408	0.0	8.830	4.775			Vel = 16.04	
22 to 21	0.0	1.049 120	0.0 0.0	12.583 0.0	21.734 0.0				
	43.2	0.5408	0.0	12.583	6.805			Vel = 16.04	
21 to 20	0.0	1.38 120	2E 6.0 0.0	21.750 6.000	28.539 0.0				
	43.2	0.1422	0.0	27.750	3.947			Vel = 9.27	
20 to 4	0.0	1.38 120	1E 3.0 0.0	9.500 3.000	32.486 4.045				
	43.2	0.1422	0.0	12.500	1.777			Vel = 9.27	
4 to 3	0.0	1.38 120	1T 6.0 0.0	1.330 6.000	38.308 0.0				
	43.2	0.1423	0.0	7.330	1.043			Vel = 9.27	
3 to 2	0.0	1.38 120	1E 3.0 0.0	7.583 3.000	39.351 0.0				
	43.2	0.1422	0.0	10.583	1.505			Vel = 9.27	
2 to 1	0.0	1.38 120	1S 7.0 0.0	5.660 7.000	40.856 2.884				
	43.2	0.1423	0.0	12.660	1.801			Vel = 9.27	
1 to TEST	0.0	1.38 120	1E 3.0 0.0	1.000 3.000	45.541 0.0				
	43.2	0.1422	0.0	4.000	0.569			Vel = 9.27	
	0.0 43.20					46.110		K Factor = 6.36	

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
-----------------------	--------------	----------------------	---------------------------	-------------------------	----------------	----------------	-------	-------	-------
