

OCEAN PARK LAND SURVEYING LLC

April 27, 2010

City of Portland
Nick Adams
Inspections Dept.
389 Congress Street
Portland, Maine 04101

Subject: Verification of footings and foundation at 37 Grafton Street.

Please accept this letter as certification that the footings and foundation being constructed at 37 Grafton Street are in same position in relation to the boundary lines as they are shown on the approved site plan for this lot.

On April 27, 2010, I personally visited the site and measured the location of the footings for the foundation. Once I verified that the footings were in their correct location I marked on the poured concrete the outside corners of the foundation.

The front of the foundation is situated 31 feet from the front boundary/street line.


The right side of the foundation, as you face the proposed foundation, is situated 13.4 feet from the boundary line.

The left side of the foundation, as you face the proposed foundation, is situated 10.6 feet from the boundary line.


The rear of the foundation is situated 35 feet from the rear boundary line.

Please feel free to call or email me with questions or comments.

Sincerely,



Robert T. Greenlaw PLS



P.O. Box 265
Ocean Park, Maine 04063
Oceanparkllc@ghi.net
207-749-9471