


CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

September 25, 2017

JHA ASSISTED LIVING INC
 630 OCEAN AVE
 PORTLAND ME 04103

Location 640 OCEAN AVE	CBL 170 A020003	Inspection Date 8/24/2017
Inspector Brad James	Inspection Type FP Routine Inspection Commerci	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 10/15/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
<p>NFPA 1- 18.2.2.1 FIRE DEPARTMENT KNOX BOX REQ; The AHJ shall have the authority to require an access box(es) to be installed in an accessible location where access to or within a structure or area is difficult because of security. The access box(es) shall be of an approved type listed in accordance with UL 1037. Properties with fire alarm systems and fire supression systems require Knox access.</p> <p>Need knox box at Delta side entrance near FDC. Also allows access to fire alarm panel in the basement.</p>	10/20/17
<p>NFPA 101- 7.5.1.1 AND 7.5.1.1.1 OBSTRUCTED EGRESS; Exits shall be located and exit access shall be arranged so that exits are readily accesible at all times (7.5.1.1). Where exits are not immediately accessible from an open floor area, continuous passageways, aisles, or corridors leading directly to every exit shall be maintained and shall be arranged to provide access for each occupant to not less than two exits by separate ways of travel, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4 (7.5.1.1.1).</p> <p>Basement hallway near generator room, elevator door and maintenance office is accumulating storage in a means of egress. All material must be removed.</p>	10/5/17
<p>NFPA 1- 34.3.2.4 COMBUSTIBLES TOO CLOSE TO HEAT SOURCE; The clearance between stored materials and unit heaters, radiant space heaters, duct furnaces, and flues shall not be less than 3 ft in all directions or shall be in accordance with the clearances shown on the approval agency label.</p> <p>Generator room storage too close to generator. This is a utility room and not a storage room and should be treated as such.</p>	10/5/17
<p>NFPA 101- 10.2.4.1 CEILING TILES MISSING; The use of textile materials on walls or ceilings shall comply with one of the following conditions: (See NFPA 101-10.2.4.1 for conditions)</p> <p>Numerous places in building. Basement had breakroom, hallway and boiler room over sprinkler valve.</p>	10/6/17

Violation	Proposed Date of Completion
FINAL DATE OF COMPLETED VIOLATION(S) <i>Final date will be when we receive Knox Box, Proposed arrival date is 10/15/17</i>	___/___/___
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	___/___/___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

10-6-17
Date

Brian R Shuta
Responsible Party

Date

Responsible Party

SEEN AND AGREED

10/16/17
Date

CHOT. JBB
Fire Prevention Bureau