
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager ESTES DIEHL J &		Inspector Jon Rioux	Inspection Date 1/9/2007
Location 916 WASHINGTON AVE	CBL 170 B003001	Status Posting Notice	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-120.1 thru 5	Interior	3		Attic	03/05/2007
Violation:	Posted against occupancy.				
Notes:	Under the current arrangement the third floor does not meet the necessary egress requirements for human habitation				
2) 105.1	Interior	3		Attic	03/05/2207
Violation:	Building w/o Permit				
Notes:	A building permit must be obtained in order to occupy the third floor for purposes other than "attic" storage.				

Comments: