DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

BROWN JB & SONS

Located at

31 Pleasant Hill Dr (901 Washington)

PERMIT ID: 2014-01693

ISSUE DATE: 10/28/2014

170 F001001 CBL:

has permission to

Interior renovations to build additional offices (20,100 SF) within the original building on-site

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

offices in several buildings on the lot

Use Group: B Type: 2B

Occupancy = business, Spurwink

Services

Occupancy load = 202 Building is sprinkled First Floor Left Side MUBEC/IBC 2009

CBL: 170 F001001 **PERMIT ID:** 2014-01693 Located at: 31 Pleasant Hill Dr (901

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping
Electrical Close-in w/Fire & Draftstopping
Above Ceiling Inspection
Final Inspection
Final - Electric
Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

PERMIT ID: 2014-01693 **Located at:** 31 Pleasant Hill Dr (901 **CBL:** 170 F001001

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 07/30/2014 2014-01693 170 F001001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: Proposed Project Description: Interior renovations to build additional offices (20,100 SF) within Same: offices in several buildings the original building on-site **Dept:** Zoning Status: Approved w/Conditions Reviewer: Marge Schmuckal **Approval Date:** 08/08/2014 Ok to Issue: Note: **Conditions:** 1) Separate permits shall be required for any new signage. Reviewer: Laurie Leader 10/28/2014 Building **Status:** Approved w/Conditions **Approval Date:** Dept: Note: Ok to Issue:

Conditions:

- 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.
- 3) Penetrations through fire resistance rated assemblies shall be protected by an approved penetration firestop system installed as tested in accordance with ASTM E814 or UL 1479

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** Craig Messinger **Approval Date:** 10/23/2014 **Note:** • Ok to Issue: ✓

Conditions:

- 1) Shall comply with NFPA 101, Chapter 39, Existing Business Occupancies
- 2) All outstanding code violations shall be corrected prior to final inspection.
- 3) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.
- 4) Shall meet the requirements of 2009 NFPA 1 Fire Code.
- 5) All construction shall comply with City Code Chapter 10.

PERMIT ID: 2014-01693 **Located at:** 31 Pleasant Hill Dr (901 **CBL:** 170 F001001