


Fire Extinguishers



Josef Chalath, Architect
 327 Ocean House Road, Cape Elizabeth, Maine 04107
 ph. 207 318 3234, email: azimuth@maine.rr.com

Code Analysis
 January 23, 2017

Tenant Space Renovation, Maine Health
 901 Washington Avenue, Portland ME
 Code Analysis

Diagram
9

Fire Extinguishers NFPA 10, Table 6.2.1.1
 Ordinary Hazard, 8881 sf
 (3) 4-A extinguishers:
 75' maximum travel distance from any point in space

