


Exit Access and Remoteness of Exits



Josef Chalal, Architect
 327 Ocean House Road, Cape Elizabeth, Maine 04107
 ph. 207 318 3234, email: azimuth@maine.rr.com

Code Analysis
 January 23, 2017

Tenant Space Renovation, Maine Health
 901 Washington Avenue, Portland ME
 Code Analysis

Diagram
7

Largest Diagonal in space: 134'-2"
 Remoteness of Exits: 66'-0"
 Ratio = .49 exceeds minimum remoteness requirement
 note that remoteness of exit access to discharge B at location A is required to be $\frac{1}{3}$ of the diagonal. See discussion in NFPA 101 7.5.1.3
 Ratio of remoteness at Conference room = .78, exceeds required minimum

