

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK
CITY OF PORTLAND

Please Read Application And Notes, If Any, Attached

BUILDING DEPARTMENT

PERMIT

Permit Number: 07-1198

This is to certify that INGRAHAM DAVID A B & EBORAH TBD

has permission to New stairway to create egress from 3rd floor

AT 9 RAY ST

172 G007001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is closed or enclosed-in. HOUR NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. Craig Evans

Health Dept. _____

Appeal Board _____

Other _____
Department Name

19/10/07 Cheryl K
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

Closes 5 min 7/28/09

0

11/14/07 - Treads & Risers OK For 2 flights - open
Risers (must drop-in) - all others OK.

Handrail?

Jim

12/30/08 Recheck risers have less than 4" opening -
S.M.H.

06/08/09 risers change to less than 4" opening -
S.M.H.