

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK

CITY OF PORTLAND

BU TION

Please Read
Application And
Notes, If Any.
Attached

Permit Number: 090047
ISSUED
JAN 28 2009
CITY OF PORTLAND

This is to certify that INGRAHAM DAVID A B & D BORAH property owner
has permission to interior repairs required for Leg zation, s s, fire
AT 9 RAY ST CE 172 G007001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is lathed or otherwise red-in. 24 HOURS NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. CAPT. R. [Signature]
Health Dept. _____
Appeal Board _____
Other _____
Department Name

[Signature] 1/28/09
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

6/08/09 Repairs as requested - completed SMA
Fire doors on 2+3rd front entrance only
3rd floor has separate exit openings

will wait for eyes, stairs properly secured
SMA

7/08/09 Eyes stairs have been beefed up
ok to close / SMA /
