



GENERAL NOTES:
 1. VERIFY ALL EXISTING RADIATION DAMPER FOR ALL PERMITATION THROUGH FIRE RATED CEILING.
 2. LOCATE ALL FAN COIL UNITS, AIR HANDLING UNITS, AND ROOF TOP UNITS.
 3. ALL CEILING ACCESS PANELS SHOULD BE FIRE RATED.

DESIGN DATA:

OUTSIDE	70° F
WINTER	850BT/720W F
SUMMER	78° F
BOILER WATER:	RESET FROM 140° F TO 180° F

Revisions

No.	Date
1	03/20/06
2	10/05/06
3	11/22/06

GENERAL REVISIONS
 FINAL PRICING
 HUD FIRM COMMITMENT

Project:
THE INN
AT CEDARS
 PORTLAND, MAINE

Drawing Title
SECOND FLOOR
HVAC PIPING PLAN

Tsomidis Associates
 Architects and Planners
 389 Elliot Street
 Newton Upper Falls, MA 02464
 (617) 968-4774 Fax (617) 968-4783
 e-mail: info@tsomidis.com www.tsomidis.com

PROFESSIONAL SEAL
 REGISTERED PROFESSIONAL ENGINEER
 MECHANICAL
 3917
 10/05/06

DATE ISSUED: 02/05/06 BID SET
SCALE: 1/8" = 1'-0"
DRAWING NUMBER:

ZADE COMPANY INC.
 CONSULTING ENGINEERS
 140 BRACKEN STREET, BOSTON, MA 02111
 TEL: (617) 388-4400
 FAX: (617) 388-4401
 E-MAIL: zade@zade.com

H-2